

| Tanks Data                                                                                                                                              |                                                                                                     | 30 DAYS WALK THROUGH INSPECTION          |                                                               |  |  |
|---------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------|------------------------------------------|---------------------------------------------------------------|--|--|
| UST Facility I.D. (FID) #                                                                                                                               | 25298                                                                                               | Contact Number                           |                                                               |  |  |
| Facility Name                                                                                                                                           | ARCO                                                                                                | Contact email                            |                                                               |  |  |
| Address                                                                                                                                                 | 5034 E Raymond St Indianapolis                                                                      | Date of Inspection                       | 5/2/23                                                        |  |  |
| Operator on Duty Name                                                                                                                                   | 46203                                                                                               | Name of the Person Conducting Inspection | Josh Rider                                                    |  |  |
| <b>Operator Training</b>                                                                                                                                |                                                                                                     |                                          |                                                               |  |  |
| Operator Training current                                                                                                                               | <input checked="" type="radio"/> Yes <input type="radio"/> No                                       | Operator Notified                        | <input type="radio"/> Yes <input type="radio"/> No            |  |  |
| <b>Registration/Notification Form</b>                                                                                                                   |                                                                                                     |                                          |                                                               |  |  |
| Is Registration current with correct owner, operator etc.                                                                                               | <input type="radio"/> Yes <input type="radio"/> No                                                  | Operator Notified                        | <input type="radio"/> Yes <input type="radio"/> No            |  |  |
| <b>Release Detection</b>                                                                                                                                |                                                                                                     |                                          |                                                               |  |  |
| Release Detection Method                                                                                                                                | <input checked="" type="radio"/> ATG <input checked="" type="radio"/> PIM <input type="radio"/> SIR | <input type="radio"/> IC                 | <input type="radio"/> Other                                   |  |  |
| Make and Model                                                                                                                                          | VR                                                                                                  | TLS-450                                  |                                                               |  |  |
| Does it have paper?                                                                                                                                     | <input checked="" type="radio"/> Yes <input type="radio"/> No                                       | Operator Notified                        | <input type="radio"/> Yes <input type="radio"/> No            |  |  |
| Is it in Alarm mode?                                                                                                                                    | <input type="radio"/> Yes <input checked="" type="radio"/> No                                       | Operator Notified                        | <input type="radio"/> Yes <input type="radio"/> No            |  |  |
| Interstitial Monitoring Sensor Status Normal                                                                                                            | <input checked="" type="radio"/> Yes <input type="radio"/> No                                       | Operator Notified                        | <input type="radio"/> Yes <input type="radio"/> No            |  |  |
| Necessary Monthly Printout Taken                                                                                                                        | <input checked="" type="radio"/> Yes <input type="radio"/> No                                       | Operator Notified                        | <input type="radio"/> Yes <input type="radio"/> No            |  |  |
| <b>Spill Buckets</b>                                                                                                                                    |                                                                                                     |                                          |                                                               |  |  |
| Are Spill Buckets Clean and free from water, debris, product etc?                                                                                       | <input type="radio"/> Yes <input checked="" type="radio"/> No                                       | Operator Notified                        | <input checked="" type="radio"/> Yes <input type="radio"/> No |  |  |
| Are the Spill Bucket in good condition and free of damage/cracks                                                                                        | <input checked="" type="radio"/> Yes <input type="radio"/> No                                       | Operator Notified                        | <input type="radio"/> Yes <input type="radio"/> No            |  |  |
| <b>Fill Ports</b>                                                                                                                                       |                                                                                                     |                                          |                                                               |  |  |
| Is Fill pipe cap tight and fill pipe free from any obstruction?                                                                                         | <input checked="" type="radio"/> Yes <input type="radio"/> No                                       | Operator Notified                        | <input type="radio"/> Yes <input type="radio"/> No            |  |  |
| <b>Piping/STP Sumps</b>                                                                                                                                 |                                                                                                     |                                          |                                                               |  |  |
| Are Sumps Clean and free from water, debris, product etc?                                                                                               | <input type="radio"/> Yes <input checked="" type="radio"/> No                                       | Operator Notified                        | <input checked="" type="radio"/> Yes <input type="radio"/> No |  |  |
| <b>Under Dispenser Containments (UDC)</b>                                                                                                               |                                                                                                     |                                          |                                                               |  |  |
| Are UDCs clean and free from water, debris, product etc?                                                                                                | <input type="radio"/> Yes <input checked="" type="radio"/> No                                       | Operator Notified                        | <input checked="" type="radio"/> Yes <input type="radio"/> No |  |  |
| NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR. |                                                                                                     |                                          |                                                               |  |  |
| Operator on Duty Name                                                                                                                                   | 317-645-0215                                                                                        | Signature                                | Date                                                          |  |  |
|                                                                                                                                                         |                                                                                                     | tanksdata@gmail.com                      | www.tanksdata.com                                             |  |  |

20220516

05/02/23 2:27 PM  
raymond st 66  
5034 raymond st  
indianapolis, in  
317-602-4545

Sensor Status Report -  
All Sensors

| #   | Sensor Location      | Status |
|-----|----------------------|--------|
| L 1 | UNLEADED             | NORMAL |
| L 2 | PREMIUM              | NORMAL |
| L 3 | DIESEL               | NORMAL |
| L 4 | UNLD INTERSTITIAL    | NORMAL |
| L 5 | PREMIUM INTERSTITIAL | NORMAL |
| L 6 | DIESEL INTERSTITIAL  | NORMAL |

05/02/23 2:29 PM

raymond st 66  
5034 raymond st  
indianapolis, in  
317-602-4545

PRESSURE LINE LEAK REPORTS  
PASSED TESTS HISTORY

Ln 1: UNLEADED

Gross Test  
Prev 24 Hours 107  
Since Midnight 65

Last Gross 05/02/23 2:26 PM  
Last Periodic 04/30/23 8:41 PM

Ln 2: PREMIUM

Gross Test  
Prev 24 Hours 4  
Since Midnight 0

Last Gross 05/01/23 10:25 PM  
Last Periodic 04/30/23 8:26 PM

Ln 3: DIESEL

Gross Test  
Prev 24 Hours 6  
Since Midnight 5

Last Gross 05/02/23 11:55 AM  
Last Periodic 05/02/23 9:57 AM

First Periodic 05/02/23 9:57 AM

05/02/23 2:31 PM

raymond st 66  
5034 raymond st  
indianapolis, in  
317-602-4545

TANK LEAK TEST HISTORY

T 1: UNLEADED

REPORT TYPE = LAST GROSS  
DATE/TIME = 05/02/23 3:35 AM  
METHOD = SLD Gross Test  
AVG. VOLUME = 3066  
VOLUME = 26.4

REPORT TYPE = LAST PERIODIC  
DATE/TIME = 05/02/23 4:07 AM  
METHOD = CSLD Periodic Test  
HOURS = 28  
AVG. VOLUME = 4709  
VOLUME = 40.6

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 05/01/23 8:56 PM  
METHOD = CSLD Periodic Test  
HOURS = 28  
AVG. VOLUME = 5008  
VOLUME = 43.2

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 04/09/23 8:57 AM  
METHOD = CSLD Periodic Test  
HOURS = 26  
AVG. VOLUME = 5763  
VOLUME = 49.7

REPORT TYPE = FULLEST PERIODIC  
DATE/TIME = 03/22/23 3:04 AM  
METHOD = CSLD Periodic Test