

REVISION 8/21/2019

Test Location Information

PC # and WO #	
Name and FID #	Amoco FID# 25298
Address	5034 E Raymond St
City/State/Zip	Indianapolis IN 46203
Contact	Jora
Phone	317-480-0009

DATE AND TIME	12-13-21 9:30-11:15
WEATHER	40 Sunny
COLLECT/INVOICE	Collect
CLIENT EMAIL	mkr2inc@gmail.com

Testing Company Information

Name	Midwest Tank Testing
Address	316 W Indiana Ave.
City/State/Zip	Chesterton, IN 46304
Phone	800-975-1436

Technician Information

Name	Jason Muller
Cert #	68-4891

TYPE OF LEAK DETECTOR - (LD) or (ELD)

PUMP #	PRODUCT	MODEL	SERIAL # (If Legible)
1	Premium	ELD	N/A
2			
3			
4			
5			
6			
7			
8			

LEAK DETECTOR TEST

PUMP #	Product Type	Metering Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Results
1	Premium	-	-	-	189ml	-	Pass
2					189ml		
3					189ml		
4					189ml		
5					189ml		
6					189ml		
7					189ml		
8					189ml		

Comments: Premium line's ELD functioned properly, sensing leak, running pump twice, and shutting down line.