

07/14/23 2:51 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

Sensor Status Report -
All Sensors

#	Sensor Location	Status
L 1	UNLEADED	NORMAL
L 2	PREMIUM	NORMAL
L 3	DIESEL	NORMAL
L 4	UNLD INTERSTITIAL	NORMAL
L 5	PREMIUM INTERSTITIAL	FUEL ALARM
L 6	DIESEL INTERSTITIAL	NORMAL

07/14/23 2:52 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

Ln 1: UNLEADED

Gross Test
Prev 24 Hours 134
Since Midnight 86

Last Gross 07/14/23 2:50 PM
Last Periodic 07/13/23 2:53 AM

First Periodic 07/01/23 3:10 AM

Ln 2: PREMIUM

Gross Test
Prev 24 Hours 16
Since Midnight 10

Last Gross 07/14/23 12:55 PM
Last Periodic 07/13/23 9:25 AM

First Periodic 07/01/23 11:10 PM

Ln 3: DIESEL

Gross Test
Prev 24 Hours 4
Since Midnight 3

Last Gross 07/14/23 2:08 PM
Last Periodic 07/13/23 2:26 PM

First Periodic 07/01/23 2:09 PM

07/14/23 2:55 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

TANK LEAK TEST HISTORY

T 1: UNLEADED

REPORT TYPE = LAST GROSS
DATE/TIME = 07/14/23 3:21 AM
METHOD = SLD Gross Test
AVG. VOLUME = 6316
VOLUME = 54.5

REPORT TYPE = LAST PERIODIC
DATE/TIME = 07/14/23 4:03 AM
METHOD = CSLD Periodic Test
HOURS = 28
AVG. VOLUME = 5911
VOLUME = 51.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/09/23 4:24 AM
METHOD = CSLD Periodic Test
HOURS = 28
AVG. VOLUME = 6389