

30 DAYS WALK THROUGH INSPECTION

Tanks Data

UST Facility I.D. (FID) # 25298

Contact Number

Facility Name AR 10

Contact email

Address 5034 E Raymond St, Indianapolis

Date of Inspection 06/25/24

Operator on Duty Name

W 46263

Name of the Person Conducting Inspection

AKSUIT SHARAB.

Operator Training current

Operator Training ☐ Yes ☐ No

Operator Notified

☐ Yes

☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form ☐ Yes ☐ No

Operator Notified

☐ Yes

☐ No

Release Detection Method

Make and Model

Does it have paper?

Is it in Alarm mode?

Interstitial Monitoring Sensor Status Normal

Necessary Monthly Printout Taken

Release Detection

☒ ATG ☐ CIM

☐ SIR

☐ IC

☐ Other

Spill Buckets

Are Spill Buckets Clean and free from water, debris, product etc?

☐ Yes ☒ No

Operator Notified

☒ Yes

☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No

Operator Notified

☐ Yes

☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

Fill Ports ☒ Yes ☐ No

Operator Notified

☐ Yes

☐ No

Are Sumps Clean and free from water, debris, product etc?

Pipeline/STP Sumps ☒ Yes ☐ No

Operator Notified

☐ Yes

☐ No

Are UDCs clean and free from water, debris, product etc?

Under Dispenser Containments (UDC) ☐ Yes ☒ No

Operator Notified

☒ Yes

☐ No

Operator on Duty Name

317-645-0215

tanksdata@gmail.com

Signature

Date

www.tanksdata.com

20220516

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.