

oil
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	25298	Contact Number	
Facility Name	PRCO	Contact email	
Address	5039 E Raymond St, Indianapolis	Date of Inspection	07/24/24
Operator on Duty Name	IN 46203	Name of the Person Conducting Inspection	AKSHIT SHARMA
Operator Training			
Operator Training current	☒ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Is Registration current with correct owner, operator etc.	☐ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Release Detection			
Release Detection Method	☒ ATG	☐ TIM	☐ SIR
Make and Model	VRS 450		
Does it have paper?	☒ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Is it in Alarm mode?	☐ Yes	☒ No	Operator Notified ☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Necessary Monthly Printout Taken	☐ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Spill Buckets			
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Fill Ports			
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Pipeline/STP Sumps			
Are Sumps Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Under Dispenser Containments (UDC)			
Are UDCs clean and free from water, debris, product etc?	☐ Yes	☒ No	Operator Notified ☒ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com 20220516