



5296 Breakers Way, Carmel, IN 46033

www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

4/4/24

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 25298
Address	5034 E Raymond St
City	Indianapolis, IN 46203
Phone	
Contact	

Technician Information

Name	Virender Kumar
Cert #	UC113039

TYPE OF LEAK DETECTOR

PUMP #	MAKE	MODEL	SERIAL#
1	Red Jacket ELLD		
2	Red Jacket ELLD		
3	Red Jacket ELLD		
4			
5			
6			
7			
8			

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	31	20		189ml		Pass
2	Premium	28	20		189ml		Fail
3	Diesel	27	20		189ml		Pass
4					189ml		.
5					189ml		.
6					189ml		.
7					189ml		.
8					189ml		.

Comment: **Ran the test twice. ATG TLS 450 would abort the test for Premium.**

Technician Signature :