



5296 Breakers Way, Carmel, IN 46033

Date

PRODUCT LINE TEST

Test Location Information

Name	FID 25298
Address	5034 E Raymond St
City	Indianapolis, IN 46203
Phone	
Contact	

Technician Information

Name	Virender Kumar
Cert #	UC113039

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
10:55am	70	0	0.0037	0	0
11:10am	69	-1	0.0037	.0037	.0148
11:25am	69	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
1:02pm	79	0	0.0037	0	0
1:17pm	77	-2	0.0037	.0074	.0296
1:32pm	76	-1	0.0037	.0037	.0148
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type : Diesel

TIME	DATA	+/-	GPL	RES	GPH
4:05pm	90	0	0.0037	0	0
4:20pm	90	0	0.0037	0	0
4:35pm	90	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result :					



5296 Breakers Way, Carmel, IN 46033

Date 4/4/24

PRODUCT LINE TEST

Test Location Information

Name	FID 25298
Address	5034 E Raymond St
City	Indianapolis
Phone	
Contact	

Technician Information

Name	Virender Kumar
Cert #	UC113039

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3	Diesel	Pass
4		.
5		.
6		.

Comment :

Tester's Name : Virender Kumar

Tester's Signature : 