

UST OVERFILL EQUIPMENT INSPECTION AUTOMATIC SHUTOFF DEVICE AND BALL FLOAT VALVE

Facility Name: ARCO	Owner: Mkr2 Inc
Address: 5034 E Raymond St	Address: 5034 E Raymond St
City, State, Zip Code: Indianapolis, IN 46203	City, State, Zip Code: Indianapolis, IN 46203
Facility I.D. #: 25298	Phone #:

This data sheet is for inspecting automatic shutoff devices and ball float valves. See PEI/RP1200 Section 7 for inspection procedures.

Product Grade	Regular	Premium	Diesel			
Tank Number	1	2	3			
Tank Volume, gallons	12000	12000	6000			
Tank Diameter, inches	96	96	96			
Overfill Prevention Device Brand						
Type	ASD ☐	ASD ☐	ASD ☐	☐	☐	☐

AUTOMATIC SHUTOFF DEVICE INSPECTION

1. Drop tube removed from tank?	Yes ☐	Yes ☐	Yes ☐			
2. Drop tube and float mechanisms free of debris?	Yes ☐	Yes ☐	Yes ☐	☐	☐	☐
3. Float moves freely without binding and poppet moves into flow path?	Yes ☐	Yes ☐	Yes ☐	☐	☐	☐
4. Bypass valve in the drop tube open and free of blockage (if present)?	Yes ☐	Yes ☐	Yes ☐	☐	☐	☐
5. Flapper adjusted to shut off flow at 95% capacity?*	Yes ☐	Yes ☐	Yes ☐	☐	☐	☐

A "No" to any item in Lines 1-5 indicates a test failure.

BALL FLOAT VALVE INSPECTION

1. Tank top fittings vapor-tight and leak-free?	☐	☐	☐	☐	☐	☐
2. Ball float cage free of debris?	☐	☐	☐	☐	☐	☐
3. Ball free of holes and cracks and moves freely in cage?	☐	☐	☐	☐	☐	☐
4. Vent hole in pipe open and near top of tank?	☐	☐	☐	☐	☐	☐
5. Ball float pipe proper length to restrict flow at 90% capacity	☐	☐	☐	☐	☐	☐

A "No" to any item in Lines 1-5 indicates a test failure.

Total Results	Pass ☐	Pass ☐	Pass ☐			
---------------	-------------------------------	-------------------------------	-------------------------------	--	--	--

Comment:

Tester's Name : Virender Kumar

Tester's Signature : 