

07/24/24 3:49 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

Sensor Status Report -
All Sensors

#	Sensor Location	Status
L 1	UNLEADED	NORMAL
L 2	PREMIUM	NORMAL
L 3	DIESEL	NORMAL
L 4	UNLD INTERSTITIAL	NORMAL
L 5	PREMIUM INTERSTITIAL	NORMAL
L 6	DIESEL INTERSTITIL	NORMAL

07/24/24 3:50 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

TANK LEAK TEST HISTORY

T 1: UNLEADED

REPORT TYPE = LAST GROSS
DATE/TIME = 07/24/24 5:10 AM
METHOD = SLD Gross Test
AVG. VOLUME = 9204
VOLUME = 79.4

REPORT TYPE = LAST PERIODIC
DATE/TIME = 07/24/24 4:01 AM
METHOD = CSLD Periodic Test
HOURS = 26
AVG. VOLUME = 6444
VOLUME = 55.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/15/24 1:48 AM
METHOD = CSLD Periodic Test
HOURS = 22
AVG. VOLUME = 6835
VOLUME = 58.9

07/24/24 3:50 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

TANK LEAK TEST HISTORY

T 2: PREMIUM

REPORT TYPE = LAST GROSS
DATE/TIME = 07/24/24 3:01 PM
METHOD = SLD Gross Test
AVG. VOLUME = 1608
VOLUME = 27.3

REPORT TYPE = LAST PERIODIC
DATE/TIME = 07/24/24 1:42 PM
METHOD = CSLD Periodic Test
HOURS = 38
AVG. VOLUME = 1664
VOLUME = 28.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/22/24 4:36 PM
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 1721
VOLUME = 29.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/03/24 11:56 AM
METHOD = CSLD Periodic Test
HOURS = 40
AVG. VOLUME = 2228
VOLUME = 37.8

07/24/24 3:50 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

TANK LEAK TEST HISTORY

T 3: DIESEL

REPORT TYPE = LAST GROSS
DATE/TIME = 07/24/24 3:20 PM
METHOD = SLD Gross Test
AVG. VOLUME = 1821
VOLUME = 30.9

REPORT TYPE = LAST PERIODIC
DATE/TIME = 07/24/24 1:03 PM
METHOD = CSLD Periodic Test
HOURS = 53
AVG. VOLUME = 1991
VOLUME = 33.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/23/24 6:50 PM
METHOD = CSLD Periodic Test
HOURS = 47
AVG. VOLUME = 2061
VOLUME = 34.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/05/24 6:24 AM
METHOD = CSLD Periodic Test
HOURS = 63
AVG. VOLUME = 1961
VOLUME = 33.3

07/24/24 3:49 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

Ln 1: UNLEADED

Gross Test

Prev 24 Hours 128
Since Midnight 75

Last Gross 07/24/24 3:48 PM
Last Periodic 07/22/24 12:16 AM

Ln 2: PREMIUM

Gross Test

Prev 24 Hours 11
Since Midnight 3

Last Gross 07/24/24 1:43 PM
Last Periodic 07/23/24 8:29 AM

Ln 3: DIESEL

Gross Test

Prev 24 Hours 1
Since Midnight 0

Last Gross 07/23/24 6:55 PM
Last Periodic 07/23/24 7:40 PM