

09/24/24 12:21 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

Ln 1: UNLEADED

Gross Test

Prev 24 Hours	86
Since Midnight	40

Last Gross	09/24/24 12:12 PM
Last Periodic	09/23/24 3:49 AM

Ln 2: PREMIUM

Gross Test

Prev 24 Hours	7
Since Midnight	3

Last Gross	09/24/24 9:30 AM
Last Periodic	09/23/24 10:56 AM
Last Annual	09/09/24 12:47 PM

First Annual	09/09/24 12:47 PM
--------------	-------------------

Ln 3: DIESEL

Gross Test

Prev 24 Hours	2
Since Midnight	1

Last Gross	09/24/24 10:09 AM
Last Periodic	09/21/24 11:10 AM
Last Annual	09/11/24 10:34 PM

First Annual	09/11/24 10:34 PM
--------------	-------------------

09/24/24 12:21 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

Sensor Status Report -
All Sensors

#	Sensor Location	Status
L 1	UNLEADED	NORMAL
L 2	PREMIUM	NORMAL
L 3	DIESEL	NORMAL
L 4	UNLD INTERSTITIAL	NORMAL
L 5	PREMIUM INTERSTITIAL	NORMAL
L 6	DIESEL INTERSTITIL	NORMAL

09/24/24 12:22 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

TANK LEAK TEST HISTORY

T 1: UNLEADED

REPORT TYPE = LAST GROSS
DATE/TIME = 09/24/24 10:46 AM
METHOD = SLD Gross Test
AVG. VOLUME = 8058
VOLUME = 69.5

REPORT TYPE = LAST PERIODIC
DATE/TIME = 09/24/24 11:45 AM
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 4262
VOLUME = 36.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/01/24 4:54 AM
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 6590
VOLUME = 56.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/29/24 2:27 AM
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 6781
VOLUME = 58.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/15/24 1:48 AM
METHOD = CSLD Periodic Test
HOURS = 22
AVG. VOLUME = 6835
VOLUME = 58.9

09/24/24 12:22 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

TANK LEAK TEST HISTORY

T 2: PREMIUM

REPORT TYPE = LAST GROSS
DATE/TIME = 09/24/24 11:50 AM
METHOD = SLD Gross Test
AVG. VOLUME = 2046
VOLUME = 34.7

REPORT TYPE = LAST PERIODIC
DATE/TIME = 09/24/24 7:35 AM
METHOD = CSLD Periodic Test
HOURS = 38
AVG. VOLUME = 1415
VOLUME = 24.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/13/24 5:52 PM
METHOD = CSLD Periodic Test
HOURS = 43
AVG. VOLUME = 1898
VOLUME = 32.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/26/24 5:51 AM
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 2105
VOLUME = 35.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/25/24 9:49 AM
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 1759
VOLUME = 29.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/03/24 11:56 AM
METHOD = CSLD Periodic Test
HOURS = 40
AVG. VOLUME = 2228
VOLUME = 37.8

REPORT TYPE = FULLEST PERIODIC

09/24/24 12:22 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

TANK LEAK TEST HISTORY

T 3: DIESEL

REPORT TYPE = LAST GROSS
DATE/TIME = 09/24/24 11:27 AM
METHOD = SLD Gross Test
AVG. VOLUME = 1019
VOLUME = 17.3

REPORT TYPE = LAST PERIODIC
DATE/TIME = 09/24/24 10:06 AM
METHOD = CSLD Periodic Test
HOURS = 70
AVG. VOLUME = 1177
VOLUME = 20.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/01/24 12:56 AM
METHOD = CSLD Periodic Test
HOURS = 73
AVG. VOLUME = 1905
VOLUME = 32.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/25/24 5:47 AM
METHOD = CSLD Periodic Test
HOURS = 45
AVG. VOLUME = 2098
VOLUME = 35.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/23/24 6:50 PM
METHOD = CSLD Periodic Test
HOURS = 47
AVG. VOLUME = 2061
VOLUME = 34.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/05/24 6:24 AM
METHOD = CSLD Periodic Test
HOURS = 63
AVG. VOLUME = 1961
VOLUME = 33.3