

10/22/25 1:57 PM

Raymond St 66
5034 Raymond St
Indianapolis, IN
317-602-4545

TANK LEAK TEST HISTORY

T 3: DIESEL

REPORT TYPE	=	LAST GROSS
DATE/TIME	=	10/22/25 12:59 PM
METHOD	=	SLD Gross Test
AVG. VOLUME	=	1882
VOLUME	=	31.9
REPORT TYPE	=	LAST PERIODIC
DATE/TIME	=	10/22/25 1:14 PM
METHOD	=	CSLD Periodic Test
HOURS	=	60
AVG. VOLUME	=	998
VOLUME	=	16.9
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	10/11/25 6:16 AM
METHOD	=	CSLD Periodic Test
HOURS	=	55
AVG. VOLUME	=	1489
VOLUME	=	25.2
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	09/10/25 8:21 AM
METHOD	=	CSLD Periodic Test
HOURS	=	67
AVG. VOLUME	=	1877
VOLUME	=	31.8
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	08/12/25 2:13 AM
METHOD	=	CSLD Periodic Test
HOURS	=	62
AVG. VOLUME	=	1440
VOLUME	=	24.4
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	07/04/25 4:01 PM
METHOD	=	CSLD Periodic Test
HOURS	=	54
AVG. VOLUME	=	1781
VOLUME	=	30.2
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	06/30/25 8:39 PM
METHOD	=	CSLD Periodic Test
HOURS	=	53
AVG. VOLUME	=	1627
VOLUME	=	27.6
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	05/02/25 12:04 PM
METHOD	=	CSLD Periodic Test
HOURS	=	73
AVG. VOLUME	=	1726
VOLUME	=	29.3
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	04/03/25 12:45 AM
METHOD	=	CSLD Periodic Test
HOURS	=	54
AVG. VOLUME	=	1769
VOLUME	=	30.0
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	03/01/25 2:25 AM
METHOD	=	CSLD Periodic Test
HOURS	=	57
AVG. VOLUME	=	1715
VOLUME	=	29.1
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	03/01/25 2:25 AM
METHOD	=	CSLD Periodic Test
HOURS	=	58
AVG. VOLUME	=	1942
VOLUME	=	32.9
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	01/24/25 1:23 AM
METHOD	=	CSLD Periodic Test
HOURS	=	59
AVG. VOLUME	=	1736
VOLUME	=	29.4
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	12/26/24 1:23 AM
METHOD	=	CSLD Periodic Test
HOURS	=	49
AVG. VOLUME	=	1556
VOLUME	=	26.4
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	11/08/24 9:04 PM
METHOD	=	CSLD Periodic Test
HOURS	=	58
AVG. VOLUME	=	1979
VOLUME	=	33.6
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	10/07/24 11:49 AM
METHOD	=	CSLD Periodic Test
HOURS	=	64
AVG. VOLUME	=	1677
VOLUME	=	28.4
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	09/01/24 12:56 AM
METHOD	=	CSLD Periodic Test
HOURS	=	73
AVG. VOLUME	=	1905
VOLUME	=	32.3
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	08/25/24 5:47 AM
METHOD	=	CSLD Periodic Test
HOURS	=	45
AVG. VOLUME	=	2098
VOLUME	=	35.6
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	07/23/24 6:50 PM
METHOD	=	CSLD Periodic Test
HOURS	=	47
AVG. VOLUME	=	2061
VOLUME	=	34.9
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	06/05/24 6:24 AM
METHOD	=	CSLD Periodic Test
HOURS	=	63
AVG. VOLUME	=	1961
VOLUME	=	33.3
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	05/01/24 12:29 PM
METHOD	=	CSLD Periodic Test
HOURS	=	68
AVG. VOLUME	=	1529
VOLUME	=	25.9
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	04/13/24 8:11 PM
METHOD	=	CSLD Periodic Test
HOURS	=	26
AVG. VOLUME	=	1960
VOLUME	=	33.2
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	03/03/24 10:54 AM
METHOD	=	CSLD Periodic Test
HOURS	=	58
AVG. VOLUME	=	1774
VOLUME	=	30.1
REPORT TYPE	=	FULLEST PERIODIC
DATE/TIME	=	02/29/24 5:16 AM
METHOD	=	
HOURS	=	56
AVG. VOLUME	=	1518
VOLUME	=	25.7

CSLD Periodic Test
 = 60
 = 1671
 = 28.3
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 12/01/23 2:16 AM
 METHOD = CSLD Periodic Test
 HOURS = 69
 AVG. VOLUME = 1714
 VOLUME = 29.1
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 11/22/23 11:22 AM
 METHOD = CSLD Periodic Test
 HOURS = 76
 AVG. VOLUME = 1818
 VOLUME = 30.8
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 10/28/23 7:45 AM
 METHOD = CSLD Periodic Test
 HOURS = 58
 AVG. VOLUME = 1491
 VOLUME = 25.3
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 09/20/23 4:35 PM
 METHOD = CSLD Periodic Test
 HOURS = 64
 AVG. VOLUME = 1514
 VOLUME = 25.7
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 08/12/23 5:58 PM
 METHOD = CSLD Periodic Test
 HOURS = 44
 AVG. VOLUME = 1627
 VOLUME = 27.6
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 07/19/23 9:59 PM
 METHOD = CSLD Periodic Test
 HOURS = 58
 AVG. VOLUME = 1537
 VOLUME = 26.1
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 06/06/23 7:38 PM
 METHOD = CSLD Periodic Test
 HOURS = 64
 AVG. VOLUME = 1836
 VOLUME = 31.1
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 05/04/23 4:37 PM
 METHOD = CSLD Periodic Test
 HOURS = 62
 AVG. VOLUME = 1792
 VOLUME = 30.4
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 04/01/23 12:17 AM
 METHOD = CSLD Periodic Test
 HOURS = 52
 AVG. VOLUME = 1277
 VOLUME = 21.7
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 03/19/23 5:19 PM
 METHOD = CSLD Periodic Test
 HOURS = 53
 AVG. VOLUME = 1778
 VOLUME = 30.1
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 02/15/23 8:44 AM
 METHOD = CSLD Periodic Test
 HOURS = 1744
 AVG. VOLUME = 29.6
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 01/09/23 10:21 AM
 METHOD = CSLD Periodic Test
 HOURS = 51
 AVG. VOLUME = 1613
 VOLUME = 27.4
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 12/01/22 2:56 AM
 METHOD = CSLD Periodic Test
 HOURS = 69
 AVG. VOLUME = 1934
 VOLUME = 32.8
 REPORT TYPE = FULLEST PERIODIC
 DATE/TIME = 11/28/22 11:47 AM
 METHOD = CSLD Periodic Test
 HOURS = 65
 AVG. VOLUME = 1951
 VOLUME = 33.1

10/22/25 1:57 PM

raymond st 66
 5034 raymond st
 indianapolis, in
 317-602-4545

Sensor Status Report -

All Sensors

#	Sensor Location	Status
L 1	UNLEADED	NORMAL
L 2	PREMIUM	NORMAL
L 3	DIESEL	NORMAL
L 4	UNLD INTERSTITIAL	NORMAL
L 5	PREMIUM INTERSTITIAL	NORMAL
L 6	DIESEL INTERSTITIL	NORMAL

10/22/25 1:59 PM

raymond st 66
 5034 raymond st
 indianapolis, in
 317-602-4545

PRESSURE LINE LEAK REPORTS

PASSED TESTS HISTORY

Ln 3: DIESEL

Gross Test

Prev 24 Hours 2

Since Midnight 2

Last Gross 10/22/25 10:09 AM

Last Periodic 10/20/25 12:39 PM

10/22/25 1:57 PM

Raymond st 66
14 raymond st
Baltimore, in
-602-4545

PRESSURE LINE LEAK REPORTS TESTED TESTS HISTORY

3: DIESEL

Test

rev 24 Hours	2
since Midnight	2

at Gross	10/22/25 10:09 AM
at Periodic	10/20/25 12:39 PM