

02/13/25 5:04 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

Ln 1: UNLEADED

Gross Test
Prev 24 Hours 81
Since Midnight 65

Last Gross 02/13/25 5:04 PM
Last Periodic 02/12/25 9:40 PM
First Periodic 02/02/25 7:54 PM

Ln 2: PREMIUM

Gross Test
Prev 24 Hours 8
Since Midnight 7

Last Gross 02/13/25 1:47 PM
Last Periodic 02/12/25 10:50 AM
First Periodic 02/04/25 1:11 PM

Ln 3: DIESEL

Gross Test
Prev 24 Hours 2
Since Midnight 2

Last Gross 02/13/25 12:00 PM
Last Periodic 02/11/25 10:04 PM
First Periodic 02/03/25 9:58 AM

02/13/25 5:04 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

Sensor Status Report -
All Sensors

#	Sensor Location	Status
L 1	UNLEADED	NORMAL
L 2	PREMIUM	NORMAL
L 3	DIESEL	NORMAL
L 4	UNLD INTERSTITIAL	NORMAL
L 5	PREMIUM INTERSTITIAL	NORMAL
L 6	DIESEL INTERSTITIL	NORMAL

02/13/25 5:05 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

TANK LEAK TEST HISTORY

T 1: UNLEADED

REPORT TYPE = LAST GROSS
DATE/TIME = 02/13/25 11:36 AM
METHOD = SLD Gross Test
AVG. VOLUME = 6690
VOLUME = 57.7

REPORT TYPE = LAST PERIODIC
DATE/TIME = 02/13/25 3:27 AM
METHOD = CSLD Periodic Test
HOURS = 26
AVG. VOLUME = 6895
VOLUME = 59.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/09/25 7:56 AM
METHOD = CSLD Periodic Test
HOURS = 24
AVG. VOLUME = 7254
VOLUME = 62.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/23/25 11:31 PM
METHOD = CSLD Periodic Test
HOURS = 22
AVG. VOLUME = 6358
VOLUME = 54.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/02/24 8:00 AM
METHOD = CSLD Periodic Test
HOURS = 25
AVG. VOLUME = 5990
VOLUME = 51.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/12/24 4:29 AM
METHOD = CSLD Periodic Test
HOURS = 26
AVG. VOLUME = 6704
VOLUME = 57.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/28/24 10:50 PM
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 6334
VOLUME = 54.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/01/24 4:54 AM
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 6031

02/13/25 5:05 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

TANK LEAK TEST HISTORY

T 2: PREMIUM

REPORT TYPE = LAST GROSS
DATE/TIME = 02/13/25 4:06 PM
METHOD = SLD Gross Test
AVG. VOLUME = 2164
VOLUME = 36.7

REPORT TYPE = LAST PERIODIC
DATE/TIME = 02/13/25 4:52 PM
METHOD = CSLD Periodic Test
HOURS = 39
AVG. VOLUME = 1274
VOLUME = 21.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/01/25 12:09 AM
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 1606
VOLUME = 27.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/30/25 7:38 PM
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 1696
VOLUME = 28.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/17/24 6:58 AM
METHOD = CSLD Periodic Test
HOURS = 42
AVG. VOLUME = 1799
VOLUME = 30.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/11/24 12:31 PM
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 1899
VOLUME = 32.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/03/24 1:58 AM
METHOD = CSLD Periodic Test
HOURS = 40
AVG. VOLUME = 1756
VOLUME = 29.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/13/24 5:52 PM
METHOD = CSLD Periodic Test
HOURS = 43
AVG. VOLUME = 1898

02/13/25 5:05 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

TANK LEAK TEST HISTORY

T 3: DIESEL

REPORT TYPE = LAST GROSS
DATE/TIME = 02/13/25 4:23 PM
METHOD = SLD Gross Test
AVG. VOLUME = 2033
VOLUME = 34.5

REPORT TYPE = LAST PERIODIC
DATE/TIME = 02/13/25 3:05 PM
METHOD = CSLD Periodic Test
HOURS = 55
AVG. VOLUME = 1019
VOLUME = 17.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/01/25 7:30 AM
METHOD = CSLD Periodic Test
HOURS = 53
AVG. VOLUME = 1431
VOLUME = 24.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/24/25 1:23 AM
METHOD = CSLD Periodic Test
HOURS = 59
AVG. VOLUME = 1736
VOLUME = 29.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/26/24 1:23 AM
METHOD = CSLD Periodic Test
HOURS = 49
AVG. VOLUME = 1556
VOLUME = 26.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/08/24 9:04 PM
METHOD = CSLD Periodic Test
HOURS = 58
AVG. VOLUME = 1979
VOLUME = 33.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/07/24 11:49 AM
METHOD = CSLD Periodic Test
HOURS = 64
AVG. VOLUME = 1677
VOLUME = 28.4