

03/08/25 4:49 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

Sensor Status Report -
All Sensors

#	Sensor Location	Status
L 1	UNLEADED	NORMAL
L 2	PREMIUM	NORMAL
L 3	DIESEL	NORMAL
L 4	UNLD INTERSTITIAL	NORMAL
L 5	PREMIUM INTERSTITIAL	NORMAL
L 6	DIESEL INTERSTITIL	NORMAL

03/08/25 4:50 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

TANK LEAK TEST HISTORY

T 1: UNLEADED

REPORT TYPE = LAST GROSS
DATE/TIME = 03/08/25 7:46 AM
METHOD = SLD Gross Test
AVG. VOLUME = 7136
VOLUME = 61.6

REPORT TYPE = LAST PERIODIC
DATE/TIME = 03/08/25 4:08 AM
METHOD = CSLD Periodic Test
HOURS = 26
AVG. VOLUME = 5449
VOLUME = 47.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/01/25 2:32 AM
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 6225
VOLUME = 53.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/09/25 7:56 AM
METHOD = CSLD Periodic Test
HOURS = 24
AVG. VOLUME = 7254
VOLUME = 62.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/23/25 11:31 PM
METHOD = CSLD Periodic Test
HOURS = 22
AVG. VOLUME = 6358
VOLUME = 54.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/02/24 8:00 AM
METHOD = CSLD Periodic Test
HOURS = 25
AVG. VOLUME = 5990
VOLUME = 51.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/12/24 4:29 AM
METHOD = CSLD Periodic Test
HOURS = 26
AVG. VOLUME = 6704
VOLUME = 57.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/28/24 10:50 PM
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 6334
VOLUME = 54.6

REPORT TYPE = FULLEST PERIODIC

03/08/25 4:50 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

TANK LEAK TEST HISTORY

T 2: PREMIUM

REPORT TYPE = LAST GROSS
DATE/TIME = 03/08/25 3:57 PM
METHOD = SLD Gross Test
AVG. VOLUME = 993
VOLUME = 16.8

REPORT TYPE = LAST PERIODIC
DATE/TIME = 03/08/25 3:07 PM
METHOD = CSLD Periodic Test
HOURS = 36
AVG. VOLUME = 1265
VOLUME = 21.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/01/25 6:15 AM
METHOD = CSLD Periodic Test
HOURS = 36
AVG. VOLUME = 1787
VOLUME = 30.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/22/25 5:24 AM
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 2083
VOLUME = 35.3

REPORT TYPE = FULLEST PERIODIC

03/08/25 4:52 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

TANK LEAK TEST HISTORY

T 3: DIESEL

REPORT TYPE = LAST GROSS
DATE/TIME = 03/08/25 3:32 PM
METHOD = SLD Gross Test
AVG. VOLUME = 1381
VOLUME = 23.4

REPORT TYPE = LAST PERIODIC
DATE/TIME = 03/08/25 4:29 PM
METHOD = CSLD Periodic Test
HOURS = 62
AVG. VOLUME = 1506
VOLUME = 25.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/01/25 2:25 AM
METHOD = CSLD Periodic Test
HOURS = 57
AVG. VOLUME = 1715
VOLUME = 29.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/20/25 7:16 AM
METHOD = CSLD Periodic Test
HOURS = 58
AVG. VOLUME = 1942
VOLUME = 32.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/24/25 1:23 AM
METHOD = CSLD Periodic Test
HOURS = 59
AVG. VOLUME = 1736