



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

4/16/25

PRODUCT LINE TEST

Test Location Information

Name	FID 25298
Address	5034 E Raymond St
City	Indianapolis, IN, 46203
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
		0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
12:15p	90	0	0.0037	0	0
12:30p	90	0	0.0037	0	0
12:45p	90	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type : Diesel

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					

#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

4/16/25

PRODUCT LINE TEST

Test Location Information

Name	FID 25298
Address	5034 E Raymond St
City	Indianapolis, IN, 46203
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	.
2	Premium	Pass
3	Diesel	.
4		.
5		.
6		.

PLT not needed for regular and diesel lines.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 