



5296 Breakers Way, Carmel, IN 46033

www.tanksdata.com
tanksdata@gmail.com
(317)-300-6065

Date 4/16/25

LEAK DETECTOR TEST (DATA SHEET)

Test Location Information

Name	FID 25298
Address	5034 E Raymond St
City	Indianapolis, IN, 46203
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Red Jacket ELLD		
Prem	Red Jacket ELLD		
Dies	Red Jacket ELLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	33	22	430 ml	189ml	2 cycles	Pass
2	Premium	40	38	510 ml	189ml	2 cycles	Pass
3	Diesel	28	26	390 ml	189ml	2 cycles	Pass
4					189ml		.
5					189ml		.
6					189ml		.
7					189ml		.
8					189ml		.

Comment:

Technician Signature :

Josh Rider