

01/09/25 4:33 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

Ln 3: DIESEL

Gross Test

Prev 24 Hours	1
Since Midnight	1

Last Gross	01/09/25	6:13 AM
Last Periodic	01/08/25	7:44 AM
First Periodic	01/04/25	7:58 AM

01/09/25 4:33 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

Sensor Status Report -
All Sensors

#	Sensor Location	Status
L 1	UNLEADED	NORMAL
L 2	PREMIUM	NORMAL
L 3	DIESEL	NORMAL
L 4	UNLD INTERSTITIAL	NORMAL
L 5	PREMIUM INTERSTITIAL	NORMAL
L 6	DIESEL INTERSTITIL	NORMAL

01/09/25 4:33 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

TANK LEAK TEST HISTORY

T 1: UNLEADED

REPORT TYPE = LAST GROSS
DATE/TIME = 01/09/25 3:17 AM
METHOD = SLD Gross Test
AVG. VOLUME = 6487
VOLUME = 56.0

REPORT TYPE = LAST PERIODIC
DATE/TIME = 01/09/25 3:59 AM
METHOD = CSLD Periodic Test
HOURS = 25
AVG. VOLUME = 4955
VOLUME = 42.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/06/25 2:55 AM
METHOD = CSLD Periodic Test
HOURS = 28
AVG. VOLUME = 5323
VOLUME = 45.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/02/24 8:00 AM
METHOD = CSLD Periodic Test
HOURS = 25
AVG. VOLUME = 5990
VOLUME = 51.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/12/24 4:29 AM
METHOD = CSLD Periodic Test
HOURS = 26
AVG. VOLUME = 6704
VOLUME = 57.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/28/24 10:50 PM
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 6334
VOLUME = 54.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/01/24 4:54 AM
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 6590
VOLUME = 56.8

01/09/25 4:35 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

TANK LEAK TEST HISTORY

T 2: PREMIUM

REPORT TYPE = LAST GROSS
DATE/TIME = 01/09/25 3:17 PM
METHOD = SLD Gross Test
AVG. VOLUME = 1534
VOLUME = 26.0

REPORT TYPE = LAST PERIODIC
DATE/TIME = 01/09/25 4:06 PM
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 1500
VOLUME = 25.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/09/25 4:06 PM
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 1500
VOLUME = 25.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/17/24 6:58 AM
METHOD = CSLD Periodic Test
HOURS = 42
AVG. VOLUME = 1799
VOLUME = 30.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/11/24 12:31 PM
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 1899
VOLUME = 32.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/03/24 1:58 AM
METHOD = CSLD Periodic Test
HOURS = 40
AVG. VOLUME = 1756
VOLUME = 29.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/13/24 5:52 PM
METHOD = CSLD Periodic Test
HOURS = 43
AVG. VOLUME = 1898
VOLUME = 32.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/26/24 5:51 AM
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 2105
VOLUME = 35.7

REPORT TYPE = FULLEST PERIODIC

01/09/25 4:37 PM

raymond st 66
5034 raymond st
indianapolis, in
317-602-4545

TANK LEAK TEST HISTORY

T 3: DIESEL

REPORT TYPE = LAST GROSS
DATE/TIME = 01/09/25 3:46 PM
METHOD = SLD Gross Test
AVG. VOLUME = 910
VOLUME = 15.4

REPORT TYPE = LAST PERIODIC
DATE/TIME = 01/09/25 3:19 PM
METHOD = CSLD Periodic Test
HOURS = 54
AVG. VOLUME = 1107
VOLUME = 18.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/01/25 12:09 AM
METHOD = CSLD Periodic Test
HOURS = 57
AVG. VOLUME = 1452
VOLUME = 24.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/26/24 1:23 AM
METHOD = CSLD Periodic Test
HOURS = 49
AVG. VOLUME = 1556
VOLUME = 26.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/08/24 9:04 PM
METHOD = CSLD Periodic Test
HOURS = 58
AVG. VOLUME = 1979
VOLUME = 33.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/07/24 11:49 AM
METHOD = CSLD Periodic Test
HOURS = 64
AVG. VOLUME = 1677
VOLUME = 28.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/01/24 12:56 AM
METHOD = CSLD Periodic Test
HOURS = 73
AVG. VOLUME = 1979
VOLUME = 33.6