

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

JUN 21, 2023 10:59 AM

LEAK TEST REPORT

T 1:PREM
PROBE SERIAL NUM 646962

TEST STARTING TIME:
JUN 21, 2023 12:30 AM

HEIGHT = 60.8 INCHES
WATER = 0.0 INCHES
TEMP = 64.9 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2543.1 GAL
PERCENT VOLUME = 50.7

LEAK TEST RESULTS
RATE = -0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

JUN 21, 2023 10:59 AM

LEAK TEST REPORT

T 2:E-85
PROBE SERIAL NUM 579362

TEST STARTING TIME:
JUN 4, 2023 12:30 AM

HEIGHT = 39.2 INCHES
WATER = 0.0 INCHES
TEMP = 59.8 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1421.4 GAL
PERCENT VOLUME = 28.3

LEAK TEST RESULTS
RATE = 0.01 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

JUN 21, 2023 10:59 AM

LEAK TEST REPORT

T 3:DIESEL 5K
PROBE SERIAL NUM 245551

TEST STARTING TIME:
JUN 14, 2023 12:30 AM

HEIGHT = 41.8 INCHES
WATER = 1.0 INCHES
TEMP = 63.1 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1553.1 GAL
PERCENT VOLUME = 31.0

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS