

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

SEP 11, 2023 11:19 AM

LEAK TEST REPORT

T 1:PREM
PROBE SERIAL NUM 646962

TEST STARTING TIME:
SEP 11, 2023 12:30 AM

HEIGHT = 67.1 INCHES
WATER = 0.0 INCHES
TEMP = 74.5 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2857.6 GAL
PERCENT VOLUME = 57.0

LEAK TEST RESULTS
RATE = 0.02 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

SEP 11, 2023 11:19 AM

LEAK TEST REPORT

T 2:E-85
PROBE SERIAL NUM 579362

TEST STARTING TIME:
SEP 11, 2023 12:30 AM

HEIGHT = 46.7 INCHES
WATER = 0.0 INCHES
TEMP = 73.0 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1787.9 GAL
PERCENT VOLUME = 35.7

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

SEP 11, 2023 11:19 AM

LEAK TEST REPORT

T 3:DIESEL 5K
PROBE SERIAL NUM 245551

TEST STARTING TIME:
SEP 11, 2023 12:30 AM

HEIGHT = 43.4 INCHES
WATER = 1.1 INCHES
TEMP = 73.6 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1624.1 GAL
PERCENT VOLUME = 32.4

LEAK TEST RESULTS
RATE = 0.05 GAL/HR
THRS = -0.13 GAL/HR