

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

MAY 17, 2023 1:01 PM

LEAK TEST REPORT

T 1:PREM
PROBE SERIAL NUM 646962

TEST STARTING TIME:
MAY 17, 2023 12:30 AM

HEIGHT = 61.4 INCHES
WATER = 0.0 INCHES
TEMP = 56.5 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2590.5 GAL
PERCENT VOLUME = 51.7

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

MAY 17, 2023 1:01 PM

LEAK TEST REPORT

T 2:E-85
PROBE SERIAL NUM 679362

TEST STARTING TIME:
MAY 17, 2023 12:30 AM

HEIGHT = 61.6 INCHES
WATER = 0.0 INCHES
TEMP = 58.2 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2595.1 GAL
PERCENT VOLUME = 51.7

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

MAY 17, 2023 1:01 PM

LEAK TEST REPORT

T 3:DIESEL 5K
PROBE SERIAL NUM 245551

TEST STARTING TIME:
MAY 17, 2023 12:30 AM

HEIGHT = 57.4 INCHES
WATER = 0.9 INCHES
TEMP = 57.4 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2370.2 GAL
PERCENT VOLUME = 47.3

LEAK TEST RESULTS
RATE = 0.07 GAL/HR
THRS = -0.13 GAL/HR