

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	2986	Contact Number	
Facility Name	MARATHON	Contact email	
Address	2101 E Michigan Blvd, Michigan City, IN 46360	Date of Inspection	4/30/22
Operator on Duty Name	IN 46360	Name of the Person Conducting Inspection	V. KEMBER

Operator Training current	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Registration/Notification Form	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Release Detection Method	☒ MTG	☐ CIM	☐ SIR	☐ IC	☐ Other
Make and Model	VR TL 350				
Does it have paper?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is it in Alarm mode?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Necessary Monthly Printout Taken	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No

Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Are UDCs clean and free from water, debris, product etc?	☐ Yes	☒ No	Operator Notified	☒ Yes	☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name	Signature	Date
317-645-0215	tanksdata@gmail.com	4/30/22

20220516