

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

DEC 7, 2023 11:52 AM

LEAK TEST REPORT

T 1:FREN
PROBE SERIAL NUM 646962

TEST STARTING TIME:
DEC 7, 2023 12:30 AM

HEIGHT = 61.5 INCHES
WATER = 0.0 INCHES
TEMP = 56.9 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2593.1 GAL
PERCENT VOLUME = 51.7

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

DEC 7, 2023 11:52 AM

LEAK TEST REPORT

T 2:E-85
PROBE SERIAL NUM 579362

TEST STARTING TIME:
DEC 7, 2023 12:30 AM

HEIGHT = 77.3 INCHES
WATER = 0.0 INCHES
TEMP = 56.9 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3421.9 GAL
PERCENT VOLUME = 68.2

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

DEC 7, 2023 11:52 AM

LEAK TEST REPORT

T 3:DIESEL 5K
PROBE SERIAL NUM 245551

TEST STARTING TIME:
DEC 7, 2023 12:30 AM

HEIGHT = 74.4 INCHES
WATER = 1.0 INCHES
TEMP = 56.9 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3272.3 GAL
PERCENT VOLUME = 65.2

LEAK TEST RESULTS
RATE = 0.11 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

DEC 7, 2023 11:52 AM

LEAK TEST REPORT

T 4:RNL 25K
PROBE SERIAL NUM 228848

TEST STARTING TIME:
DEC 5, 2023 12:30 AM

HEIGHT = 40.3 INCHES
WATER = 0.8 INCHES
TEMP = 52.6 F

TEST LENGTH = 3.0 HRS