

REVISION 8/21/2019

DATE AND TIME

6/30/2022

WEATHER

90 Sunny

COLLECT/INVOICE

Collected

CLIENT EMAIL

Testing Company Information

Test Location Information

Certifications

Name

Midwest Tank Testing

Address

316 W. Indiana Ave.

City/State/Zip

Chesterton, IN 46304

Phone

800-975-1436

Technician Information

Name

Chris Zell

Email

support@midwesttanktesting.com

TYPE OF LEAK DETECTOR - (LD) or (ELD)

PUMP #	PRODUCT	MODEL	SERIAL # (If Legible)
1	Regular	FX1V	N/A
2	Premium	FX1V	N/A
3	E85	FX1V	N/A
4	Diesel	FX1DV	N/A
5			
6			
7			
8			

LEAK DETECTOR TEST

PUMP #	Product Type	Metering Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Results
1	Regular	35	25	260	189ml	2	Pass
2	Premium	37	24	180	189ml	2	Pass
3	E85	34	24	200	189ml	2	Pass
4	Diesel	34	23	80	189ml	2	Pass
5							
6							
7							
8							

COMMENTS/RECOMMENDATIONS:



AN ENVIRONMENTAL COMPLIANCE COMPANY

316 W. Indiana Ave.
Chesterton, IN 46304

EZY CHEK SYSTEMS

PRODUCT LINE TEST

DATE AND TIME

6/30/2022

Test Location Information

PC # and WO #	
Name and FID #	Marathon FID # 2936
Address	2101 E. Michigan Blvd.
City/State/Zip	Michigan City IN 46360
Contact	
Phone	

Testing Company Information

Name	Midwest Tank Testing
Address	316 W. Indiana Ave.
City/State/Zip	Chesterton, IN 46304
Phone	800-975-1436

Technician Information

Name	Chris Zell
Email	support@midwesttanktesting.com
Applied Pressure	1-1/2 Times Working Pressure, Min 50 PSI

PRODUCT LINE TEST - DATA (LT)

#1	Product Type:		Regular		
TIME	DATA	-/+	GPL	RES	GPH
12:50	67	0	0.0037	0.0000	0.0000
1:05	65	-2	0.0037	-0.0074	-0.0296
1:20	63	-2	0.0037	-0.0074	-0.0296
1:35	63	0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:			Pass		

#2	Product Type:		Premium		
TIME	DATA	-/+	GPL	RES	GPH
12:50	40	0	0.0037	0.0000	0.0000
1:05	38	-2	0.0037	-0.0074	-0.0296
1:20	38	0	0.0037	0.0000	0.0000
1:35	38	0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:			Pass		

#3	Product Type:		E85		
TIME	DATA	-/+	GPL	RES	GPH
12:50	83	0	0.0037	0.0000	0.0000
1:05	83	0	0.0037	0.0000	0.0000
1:20	82	-1	0.0037	-0.0037	-0.0148
1:35	82	0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:			Pass		

#4	Product Type:		Diesel		
TIME	DATA	-/+	GPL	RES	GPH
12:50	95	0	0.0037	0.0000	0.0000
1:05	95	0	0.0037	0.0000	0.0000
1:20	95	0	0.0037	0.0000	0.0000
1:35	95	0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:			Pass		

#5	Product Type:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:					

#6	Product Type:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
		0	0.0037	0.0000	0.0000
FINAL RESULT:					

COMMENTS/RECOMMENDATIONS: