

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

OCT 17, 2023 10:46 AM

LEAK TEST REPORT

T 1:PREM
PROBE SERIAL NUM 646962

TEST STARTING TIME:
OCT 17, 2023 12:30 AM

HEIGHT = 58.8 INCHES
WATER = 0.0 INCHES
TEMP = 69.7 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2429.5 GAL
PERCENT VOLUME = 48.4

LEAK TEST RESULTS
RATE = 0.02 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

OCT 17, 2023 10:46 AM

LEAK TEST REPORT

T 2:E-85
PROBE SERIAL NUM 579362

TEST STARTING TIME:
OCT 17, 2023 12:30 AM

HEIGHT = 57.9 INCHES
WATER = 0.0 INCHES
TEMP = 69.8 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2381.6 GAL
PERCENT VOLUME = 47.5

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

OCT 17, 2023 10:46 AM

LEAK TEST REPORT

T 3:DIESEL 5K
PROBE SERIAL NUM 245551

TEST STARTING TIME:
OCT 17, 2023 12:30 AM

HEIGHT = 60.0 INCHES
WATER = 1.0 INCHES
TEMP = 69.9 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2496.9 GAL
PERCENT VOLUME = 49.8

LEAK TEST RESULTS
RATE = 0.01 GAL/HR
THRS = -0.13 GAL/HR