

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

MAY 10, 2024 12:37 PM

LEAK TEST REPORT

T 1:PREM
PROBE SERIAL NUM 646962

TEST STARTING TIME:
MAY 10, 2024 12:30 AM

HEIGHT = 60.3 INCHES
WATER = 0.0 INCHES
TEMP = 57.6 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 2525.6 GAL
PERCENT VOLUME = 50.4

LEAK TEST RESULTS
RATE = 0.13 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

LEAK TEST STATUS:
TEST NOT IN PROGRESS

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

MAY 10, 2024 12:37 PM

LEAK TEST REPORT

T 2:E-85
PROBE SERIAL NUM 579362

TEST STARTING TIME:
MAY 10, 2024 12:30 AM

HEIGHT = 76.3 INCHES
WATER = 0.0 INCHES
TEMP = 56.7 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3373.2 GAL
PERCENT VOLUME = 67.3

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *