

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

FEB 5, 2024 2:07 PM

LEAK TEST REPORT

T 1:PREM
PROBE SERIAL NUM 646962

TEST STARTING TIME:
FEB 5, 2024 12:30 AM

HEIGHT = 66.9 INCHES
WATER = 0.0 INCHES
TEMP = 46.1 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2899.5 GAL
PERCENT VOLUME = 57.8

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

FEB 5, 2024 2:08 PM

LEAK TEST REPORT

T 2:E-85
PROBE SERIAL NUM 579362

TEST STARTING TIME:
FEB 5, 2024 12:30 AM

HEIGHT = 59.7 INCHES
WATER = 0.0 INCHES
TEMP = 48.2 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2511.0 GAL
PERCENT VOLUME = 50.1

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

FEB 5, 2024 2:08 PM

LEAK TEST REPORT

T 4:RNL 25K
PROBE SERIAL NUM 228848

TEST STARTING TIME:
FEB 3, 2024 12:30 AM

HEIGHT = 40.7 INCHES
WATER = 0.8 INCHES
TEMP = 41.2 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 7629.1 GAL
PERCENT VOLUME = 30.3

LEAK TEST RESULTS
RATE = -1.40 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

***** END *****