

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

AUG 8, 2024 3:35 PM

LEAK TEST REPORT

T 1:PREM
PROBE SERIAL NUM 646962

TEST STARTING TIME:
AUG 8, 2024 12:30 AM

HEIGHT = 49.0 INCHES
WATER = 0.0 INCHES
TEMP = 72.0 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1909.4 GAL
PERCENT VOLUME = 38.1

LEAK TEST RESULTS
RATE = 0.01 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

AUG 8, 2024 3:35 PM

LEAK TEST REPORT

T 2:E-85
PROBE SERIAL NUM 579362

TEST STARTING TIME:
AUG 8, 2024 12:30 AM

HEIGHT = 66.7 INCHES
WATER = 0.0 INCHES
TEMP = 71.7 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2839.7 GAL
PERCENT VOLUME = 56.6

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

AUG 8. 2024 3:35 PM

LEAK TEST REPORT

T 3:DIESEL 5K
PROBE SERIAL NUM 245551

TEST STARTING TIME:
AUG 8. 2024 12:30 AM

HEIGHT = 48.4 INCHES
WATER = 1.1 INCHES
TEMP = 71.8 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1885.9 GAL
PERCENT VOLUME = 37.6

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

AUG 8. 2024 3:35 PM

LEAK TEST REPORT

T 4:RNL 25K
PROBE SERIAL NUM 228848

TEST STARTING TIME:
AUG 6. 2024 12:30 AM

HEIGHT = 43.4 INCHES
WATER = 0.8 INCHES
TEMP = 71.4 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 8134.7 GAL
PERCENT VOLUME = 32.3

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
PRODUCT LEVEL INCREASE

* * * * * END * * * * *