

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	2986	Contact Number	
Facility Name	Mountain	Contact email	
Address	2101 E Michigan Blvd,	Date of Inspection	04-21-2025
Operator on Duty Name	Michigan City, IN-46360	Name of the Person Conducting Inspection	Wahon Singh

Operator Training current	☐ Yes ☐ No	Operator Training	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	Registration/Notification Form	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Release Detection Method	☒ ATG ☐ CIM	Release Detection	☐ ATG ☐ CIM	Operator Notified	☐ Yes ☐ No
Make and Model	VR-TLS 350		☐ SIR ☐ IC	Operator Notified	☐ Yes ☐ No
Does it have paper?	☒ Yes ☐ No			Operator Notified	☐ Yes ☐ No
Is it in Alarm mode?	☒ Yes ☐ No			Operator Notified	☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No			Operator Notified	☐ Yes ☐ No
Necessary Monthly Printout Taken	☒ Yes ☐ No			Operator Notified	☐ Yes ☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes ☐ No	Spill Buckets		Operator Notified	☐ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No			Operator Notified	☐ Yes ☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	Fill Ports		Operator Notified	☐ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes ☐ No	Pipeline/STP Sumps		Operator Notified	☐ Yes ☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes ☐ No	Under Dispenser Containments (UDC)		Operator Notified	☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com 20220516