

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

JUL 5, 2025 5:20 PM

LEAK TEST REPORT

T 1:PREM
PROBE SERIAL NUM 646962

TEST STARTING TIME:
JUL 5, 2025 12:30 AM

HEIGHT = 58.6 INCHES
WATER = 0.0 INCHES
TEMP = 69.4 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2416.3 GAL
PERCENT VOLUME = 48.2

LEAK TEST RESULTS
RATE = -0.01 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

JUL 5, 2025 5:20 PM

LEAK TEST REPORT

T 2:E-85
PROBE SERIAL NUM 579362

TEST STARTING TIME:
JUL 5, 2025 12:30 AM

HEIGHT = 66.4 INCHES
WATER = 0.0 INCHES
TEMP = 66.3 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2836.8 GAL
PERCENT VOLUME = 56.6

LEAK TEST RESULTS
RATE = -0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

JUL 5, 2025 5:20 PM

LEAK TEST REPORT

T 4:RNL 25K
PROBE SERIAL NUM 228848

TEST STARTING TIME:
JUL 5, 2025 12:30 AM

HEIGHT = 43.8 INCHES
WATER = 0.8 INCHES
TEMP = 71.5 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 8232.5 GAL
PERCENT VOLUME = 32.7

LEAK TEST RESULTS
RATE = -5.65 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *