

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

OCT 10, 2025 4:53 PM

LEAK TEST REPORT

T 1:FRED
PROBE SERIAL NUM 646962

TEST STARTING TIME:
OCT 10, 2025 12:30 AM

HEIGHT = 42.4 INCHES
WATER = 0.0 INCHES
TEMP = 71.7 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 1574.0 GAL
PERCENT VOLUME = 31.4

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
RECENT DELIVERY
CHANGE IN TANK TEMP ZONE
TEMP CHANGE TOO LARGE
PRODUCT LEVEL INCREASE

***** END *****

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

OCT 10, 2025 4:53 PM

LEAK TEST REPORT

T 2:E-85
PROBE SERIAL NUM 579362

TEST STARTING TIME:
OCT 10, 2025 12:30 AM

HEIGHT = 66.6 INCHES
WATER = 0.0 INCHES
TEMP = 71.9 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2835.2 GAL
PERCENT VOLUME = 56.5

LEAK TEST RESULTS
RATE = -0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

OCT 10, 2025 4:53 PM

LEAK TEST REPORT

T 3:DIESEL 5K
PROBE SERIAL NUM 245551

TEST STARTING TIME:
OCT 10, 2025 12:30 AM

HEIGHT = 45.5 INCHES
WATER = 1.4 INCHES
TEMP = 71.8 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 1734.8 GAL
PERCENT VOLUME = 34.6

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
PRODUCT LEVEL INCREASE

***** END *****

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

OCT 10, 2025 4:53 PM

LEAK TEST REPORT

T 4:RNL 25K
PROBE SERIAL NUM 228848

TEST STARTING TIME:
OCT 5, 2025 12:30 AM

HEIGHT = 45.9 INCHES
WATER = 0.0 INCHES
TEMP = 69.0 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 8794.5 GAL
PERCENT VOLUME = 35.0

LEAK TEST RESULTS
RATE = 0.10 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****