

HANDY SPOT  
2101 E MICH BLVD  
MICHIGAN CITY  
219-878-9790

MAR 7, 2025 5:44 PM

LEAK TEST REPORT

T 1:PREM  
PROBE SERIAL NUM 646962

TEST STARTING TIME:  
MAR 7, 2025 12:30 AM

HEIGHT = 46.1 INCHES  
WATER = 0.0 INCHES  
TEMP = 45.9 F

TEST LENGTH = 2.0 HRS  
STRT VOLUME = 1793.5 GAL  
PERCENT VOLUME = 35.8

LEAK TEST RESULTS  
RATE = 0.00 GAL/HR  
THRS = -0.13 GAL/HR  
0.20 GAL/HR TEST PASS

\* \* \* \* \* END \* \* \* \* \*

HANDY SPOT  
2101 E MICH BLVD  
MICHIGAN CITY  
219-878-9790

MAR 7, 2025 5:44 PM

LEAK TEST REPORT

T 1:PREM  
PROBE SERIAL NUM 646962

TEST STARTING TIME:  
MAR 7, 2025 12:30 AM

HEIGHT = 46.1 INCHES  
WATER = 0.0 INCHES  
TEMP = 45.9 F

TEST LENGTH = 2.0 HRS  
STRT VOLUME = 1793.5 GAL  
PERCENT VOLUME = 35.8

LEAK TEST RESULTS  
RATE = 0.00 GAL/HR  
THRS = -0.13 GAL/HR  
0.20 GAL/HR TEST PASS

\* \* \* \* \* END \* \* \* \* \*

LEAK TEST STATUS:  
TEST NOT IN PROGRESS

HANDY SPOT  
2101 E MICH BLVD  
MICHIGAN CITY  
219-878-9790

MAR 7, 2025 5:45 PM

LEAK TEST REPORT

T 2:E-85  
PROBE SERIAL NUM 579362

TEST STARTING TIME:  
MAR 7, 2025 12:30 AM

HEIGHT = 65.8 INCHES  
WATER = 0.0 INCHES  
TEMP = 45.9 F

TEST LENGTH = 2.0 HRS  
STRT VOLUME = 2843.7 GAL  
PERCENT VOLUME = 56.7

LEAK TEST RESULTS  
RATE = -0.00 GAL/HR  
THRS = -0.13 GAL/HR  
0.20 GAL/HR TEST PASS

\* \* \* \* \* END \* \* \* \* \*

HANDY SPOT  
2101 E MICH BLVD  
MICHIGAN CITY  
219-878-9790

MAR 7, 2025 5:45 PM

LEAK TEST REPORT

T 2:E-85  
PROBE SERIAL NUM 579362

TEST STARTING TIME:  
MAR 7, 2025 12:30 AM

HEIGHT = 65.8 INCHES  
WATER = 0.0 INCHES  
TEMP = 45.9 F

TEST LENGTH = 2.0 HRS  
STRT VOLUME = 2843.7 GAL  
PERCENT VOLUME = 56.7

LEAK TEST RESULTS  
RATE = -0.00 GAL/HR  
THRS = -0.13 GAL/HR  
0.20 GAL/HR TEST PASS

\* \* \* \* \* END \* \* \* \* \*

HANDY SPOT  
2101 E MICH BLVD  
MICHIGAN CITY  
219-878-9790

MAR 7, 2025 5:45 PM

LEAK TEST REPORT

T 4:RNL 25K  
PROBE SERIAL NUM 228848

TEST STARTING TIME:  
MAR 3, 2025 12:30 AM

HEIGHT = 43.0 INCHES  
WATER = 0.8 INCHES  
TEMP = 40.0 F

TEST LENGTH = 2.0 HRS  
STRT VOLUME = 8206.5 GAL  
PERCENT VOLUME = 32.6

LEAK TEST RESULTS  
RATE = -0.00 GAL/HR  
THRS = -0.13 GAL/HR  
0.20 GAL/HR TEST PASS

\* \* \* \* \* END \* \* \* \* \*

HANDY SPOT  
2101 E MICH BLVD  
MICHIGAN CITY  
219-878-9790

MAR 7, 2025 5:45 PM

LEAK TEST REPORT

T 4:RNL 25K  
PROBE SERIAL NUM 228848

TEST STARTING TIME:  
MAR 3, 2025 12:30 AM

HEIGHT = 43.0 INCHES  
WATER = 0.8 INCHES  
TEMP = 40.0 F

TEST LENGTH = 2.0 HRS  
STRT VOLUME = 8206.5 GAL  
PERCENT VOLUME = 32.6

LEAK TEST RESULTS  
RATE = -0.00 GAL/HR  
THRS = -0.13 GAL/HR  
0.20 GAL/HR TEST PASS

\* \* \* \* \* END \* \* \* \* \*