

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

NOV 13, 2024 3:17 PM

LEAK TEST REPORT

T 1:PREM
PROBE SERIAL NUM 646962

TEST STARTING TIME:
NOV 13, 2024 12:30 AM

HEIGHT = 54.3 INCHES
WATER = 0.0 INCHES
TEMP = 65.7 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2196.6 GAL
PERCENT VOLUME = 43.8

LEAK TEST RESULTS
RATE = 0.02 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

NOV 13, 2024 3:17 PM

LEAK TEST REPORT

T 2:E-85
PROBE SERIAL NUM 579362

TEST STARTING TIME:
NOV 13, 2024 12:30 AM

HEIGHT = 66.5 INCHES
WATER = 0.0 INCHES
TEMP = 66.0 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2840.3 GAL
PERCENT VOLUME = 56.6

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

NOV 13, 2024 3:17 PM

LEAK TEST REPORT

T 3:DIESEL 5K
PROBE SERIAL NUM 245551

TEST STARTING TIME:
NOV 13, 2024 12:30 AM

HEIGHT = 57.6 INCHES
WATER = 1.2 INCHES
TEMP = 66.0 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2374.5 GAL
PERCENT VOLUME = 47.3

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

NOV 13, 2024 3:17 PM

LEAK TEST REPORT

T 4:RNL 25K
PROBE SERIAL NUM 228848

TEST STARTING TIME:
NOV 10, 2024 12:30 AM

HEIGHT = 41.5 INCHES
WATER = 0.8 INCHES
TEMP = 60.4 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 7723.5 GAL
PERCENT VOLUME = 30.7

LEAK TEST RESULTS
RATE = -2.96 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *