



5296 Breakers Way, Carmel, IN 46033

Date

7/8/25

PRODUCT LINE TEST

Test Location Information

Name	FID 2986
Address	2101 E Michigan Blvd
City	Michigan City
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
11:55am	78	0	0.0037	0	0
12:10pm	77	-1	0.0037	.0037	.0148
12:25pm	77	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		

Final Result : Pass

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
12:45pm	84	0	0.0037	0	0
1:00pm	83	-1	0.0037	.0037	.0148
1:15pm	82	-1	0.0037	.0037	.0148
			0.0037		
			0.0037		
			0.0037		
			0.0037		

Final Result : Pass

#3 Product Type : Diesel

TIME	DATA	+/-	GPL	RES	GPH
1:35pm	90	0	0.0037	0	0
1:50pm	90	0	0.0037	0	0
2:05pm	90	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		

Final Result : Pass

#4 Product Type : E-85

TIME	DATA	+/-	GPL	RES	GPH
		0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		

Final Result : .



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date 7/8/25

PRODUCT LINE TEST

Test Location Information		Technician Information	
Name	FID 2986	Name	Josh Rider
Address	2101 E Michigan Blvd	Cert #	UC202406986
City	Michigan City		
Phone			
Contact			

Applied Pressure
50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3	Diesel	Pass
4	E-85	.
5		.
6		.

E-85 is currently not working. Unable to test until it is working properly.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 