

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

OCT 14, 2024 3:55 PM

LEAK TEST REPORT

T 1:PREM
PROBE SERIAL NUM 646962

TEST STARTING TIME:
OCT 14, 2024 12:30 AM

HEIGHT = 52.8 INCHES
WATER = 0.0 INCHES
TEMP = 71.2 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2108.7 GAL
PERCENT VOLUME = 42.0

LEAK TEST RESULTS
RATE = 0.01 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

OCT 14, 2024 3:55 PM

LEAK TEST REPORT

T 2:E-85
PROBE SERIAL NUM 579362

TEST STARTING TIME:
OCT 14, 2024 12:30 AM

HEIGHT = 66.7 INCHES
WATER = 0.0 INCHES
TEMP = 71.5 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2839.6 GAL
PERCENT VOLUME = 56.6

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

OCT 14, 2024 3:55 PM

LEAK TEST REPORT

T 3:DIESEL 5K
PROBE SERIAL NUM 245551

TEST STARTING TIME:
OCT 14, 2024 12:30 AM

HEIGHT = 60.3 INCHES
WATER = 1.0 INCHES
TEMP = 70.6 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2509.8 GAL
PERCENT VOLUME = 50.0

LEAK TEST RESULTS
RATE = -0.01 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

OCT 14, 2024 3:55 PM

LEAK TEST REPORT

T 4:RNL 25K
PROBE SERIAL NUM 228848

TEST STARTING TIME:
OCT 13, 2024 12:30 AM

HEIGHT = 44.1 INCHES
WATER = 0.8 INCHES
TEMP = 66.0 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 8353.8 GAL
PERCENT VOLUME = 33.2

LEAK TEST RESULTS
RATE = 0.03 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *