

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

JUL 8, 2025 11:29 AM

TANK LEAK TEST HISTORY

T 1:PREM

LAST GROSS TEST PASSED:
JUL 8, 2025 12:30 AM
STARTING VOLUME = 1994
PERCENT VOLUME = 39.8
TEST TYPE = STANDARD

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED

LAST PERIODIC TEST PASS:
JUL 8, 2025 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME = 1994
PERCENT VOLUME = 39.8
TEST TYPE = STANDARD

FULLEST PERIODIC TEST
PASSED EACH MONTH:

JAN 19, 2025 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME = 3602
PERCENT VOLUME = 71.8
TEST TYPE = STANDARD

FEB 9, 2025 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME = 3476
PERCENT VOLUME = 69.3
TEST TYPE = STANDARD

MAR 9, 2025 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME = 2656
PERCENT VOLUME = 53.0
TEST TYPE = STANDARD

APR 13, 2025 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME = 3025
PERCENT VOLUME = 60.3
TEST TYPE = STANDARD

MAY 25, 2025 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME = 2870
PERCENT VOLUME = 57.2
TEST TYPE = STANDARD

JUN 29, 2025 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME = 3002
PERCENT VOLUME = 59.9
TEST TYPE = STANDARD

JUL 1, 2025 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME = 2783
PERCENT VOLUME = 55.5
TEST TYPE = STANDARD

AUG 2, 2024 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME = 3085
PERCENT VOLUME = 61.5
TEST TYPE = STANDARD

SEP 22, 2024 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME = 3535
PERCENT VOLUME = 70.5
TEST TYPE = STANDARD

OCT 23, 2024 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME = 3238
PERCENT VOLUME = 64.6
TEST TYPE = STANDARD

NOV 3, 2024 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME = 3143
PERCENT VOLUME = 62.7
TEST TYPE = STANDARD

DEC 29, 2024 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME = 3666
PERCENT VOLUME = 73.1
TEST TYPE = STANDARD

* * * * * END * * * * *