



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

7/8/25

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 2986
Address	2101 E Michigan Blvd
City	Michigan City
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Prem	Red Jacket MLLD		
E-85	Red Jacket MLLD		
Dies	Red Jacket MLLD		
Reg	Red Jacket MLLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Premium	37	23	200 ml	189ml	2 sec	Pass
2	E-85	-	-	-	189ml	-	.
3	Diesel	33	23	260 ml	189ml	2 sec	Pass
4	Regular	35	24	250 ml	189ml	3 sec	Pass
5					189ml		.
6					189ml		.
7					189ml		.
8					189ml		.

Comment:

E-85 is currently not working. Cannot test until fixed.

Technician Signature :

