

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

JUL 8, 2025 11:29 AM

TANK LEAK TEST HISTORY

T 2:E-85

LAST GROSS TEST PASSED:
JUL 8, 2025 12:30 AM
STARTING VOLUME= 2836
PERCENT VOLUME = 56.6
TEST TYPE = STANDARD

LAST ANNUAL TEST PASSED:
OCT 20, 2022 1:00 AM
TEST LENGTH 3 HOURS
STARTING VOLUME= 3564
PERCENT VOLUME = 71.1
TEST TYPE = STANDARD

FULLEST ANNUAL TEST PASS
OCT 20, 2022 1:00 AM
TEST LENGTH 3 HOURS
STARTING VOLUME= 3564
PERCENT VOLUME = 71.1
TEST TYPE = STANDARD

LAST PERIODIC TEST PASS:
JUL 8, 2025 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME= 2836
PERCENT VOLUME = 56.6
TEST TYPE = STANDARD

FULLEST PERIODIC TEST
PASSED EACH MONTH:

JAN 29, 2025 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME= 2843
PERCENT VOLUME = 56.7
TEST TYPE = STANDARD

FEB 9, 2025 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME= 2845
PERCENT VOLUME = 56.7
TEST TYPE = STANDARD

MAR 1, 2025 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME= 2844
PERCENT VOLUME = 56.7
TEST TYPE = STANDARD

APR 13, 2025 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME= 2843
PERCENT VOLUME = 56.7
TEST TYPE = STANDARD

MAY 9, 2025 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME= 2841
PERCENT VOLUME = 56.7
TEST TYPE = STANDARD

JUN 1, 2025 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME= 2840
PERCENT VOLUME = 56.6
TEST TYPE = STANDARD

JUL 1, 2025 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME= 2837
PERCENT VOLUME = 56.6
TEST TYPE = STANDARD

AUG 1, 2024 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME= 2840
PERCENT VOLUME = 56.6
TEST TYPE = STANDARD

SEP 1, 2024 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME= 2839
PERCENT VOLUME = 56.6
TEST TYPE = STANDARD

OCT 13, 2024 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME= 2839
PERCENT VOLUME = 56.6
TEST TYPE = STANDARD

NOV 4, 2024 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME= 2840
PERCENT VOLUME = 56.6
TEST TYPE = STANDARD

DEC 17, 2024 12:30 AM
TEST LENGTH 2 HOURS
STARTING VOLUME= 2843
PERCENT VOLUME = 56.7
TEST TYPE = STANDARD

* * * * * END * * * * *