

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

SEP 21, 2024 1:13 PM

LEAK TEST REPORT

T 1:PREM
PROBE SERIAL NUM 646962

TEST STARTING TIME:
SEP 21, 2024 12:30 AM

HEIGHT = 62.8 INCHES
WATER = 0.0 INCHES
TEMP = 73.3 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2630.9 GAL
PERCENT VOLUME = 52.5

LEAK TEST RESULTS

RATE = -0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

SEP 21, 2024 1:13 PM

LEAK TEST REPORT

T 2:E-85
PROBE SERIAL NUM 579362

TEST STARTING TIME:
SEP 21, 2024 12:30 AM

HEIGHT = 66.7 INCHES
WATER = 0.0 INCHES
TEMP = 73.1 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2838.3 GAL
PERCENT VOLUME = 56.6

LEAK TEST RESULTS

RATE = -0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

SEP 21, 2024 1:13 PM

LEAK TEST REPORT

T 3:DIESEL 5K
PROBE SERIAL NUM 245551

TEST STARTING TIME:
SEP 21, 2024 12:30 AM

HEIGHT = 40.6 INCHES
WATER = 1.1 INCHES
TEMP = 72.8 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1485.1 GAL
PERCENT VOLUME = 29.6

LEAK TEST RESULTS
RATE = -0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

SEP 21, 2024 1:13 PM

LEAK TEST REPORT

T 4:RNL 25K
PROBE SERIAL NUM 228848

TEST STARTING TIME:
SEP 16, 2024 12:30 AM

HEIGHT = 43.5 INCHES
WATER = 0.8 INCHES
TEMP = 71.5 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 8162.8 GAL
PERCENT VOLUME = 32.5

LEAK TEST RESULTS
RATE = -3.38 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *