

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

SEP 14, 2025 5:31 PM

LEAK TEST REPORT

T 1:PREM
PROBE SERIAL NUM 646962

TEST STARTING TIME:
SEP 14, 2025 12:30 AM

HEIGHT = 57.2 INCHES
WATER = 0.0 INCHES
TEMP = 71.6 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2341.9 GAL
PERCENT VOLUME = 46.7

LEAK TEST RESULTS
RATE = -0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

SEP 14, 2025 5:31 PM

LEAK TEST REPORT

T 2:E-85
PROBE SERIAL NUM 579362

TEST STARTING TIME:
SEP 14, 2025 12:30 AM

HEIGHT = 66.7 INCHES
WATER = 0.0 INCHES
TEMP = 73.0 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2835.0 GAL
PERCENT VOLUME = 56.5

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

SEP 14, 2025 5:31 PM

LEAK TEST REPORT

T 3:DIESEL 5K
PROBE SERIAL NUM 245551

TEST STARTING TIME:
SEP 14, 2025 12:30 AM

HEIGHT = 40.9 INCHES
WATER = 1.5 INCHES
TEMP = 72.2 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1500.2 GAL
PERCENT VOLUME = 29.9

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

SEP 14, 2025 5:31 PM

LEAK TEST REPORT

T 2:E-85
PROBE SERIAL NUM 579362

TEST STARTING TIME:
SEP 14, 2025 12:30 AM
HEIGHT = 66.7 INCHES
WATER = 0.0 INCHES
TEMP = 73.0 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2835.0 GAL
PERCENT VOLUME = 56.5

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

SEP 14, 2025 5:31 PM

LEAK TEST REPORT

T 3:DIESEL 5K
PROBE SERIAL NUM 245551

TEST STARTING TIME:
SEP 14, 2025 12:30 AM
HEIGHT = 40.9 INCHES
WATER = 1.5 INCHES
TEMP = 72.2 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1500.2 GAL
PERCENT VOLUME = 29.9

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

SEP 14, 2025 5:31 PM

LEAK TEST REPORT

T 4:RNL 25K
PROBE SERIAL NUM 228848

TEST STARTING TIME:
SEP 12, 2025 12:30 AM
HEIGHT = 45.1 INCHES
WATER = 0.0 INCHES
TEMP = 67.0 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 8596.8 GAL
PERCENT VOLUME = 34.2

LEAK TEST RESULTS
RATE = 0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****