

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

JUN 13, 2025 4:15 PM

LEAK TEST REPORT

T 1:PREM
PROBE SERIAL NUM 640900

TEST STARTING TIME:
JUN 13, 2025 12:30 AM

HEIGHT = 45.9 INCHES
WATER = 0.0 INCHES
TEMP = 61.6 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1761.1 GAL
PERCENT VOLUME = 33.1

LEAK TEST RESULTS
RATE = 0.01 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

JUN 13, 2025 4:16 PM

LEAK TEST REPORT

T 2:E-85
PROBE SERIAL NUM 579362

TEST STARTING TIME:
JUN 13, 2025 12:30 AM

HEIGHT = 66.3 INCHES
WATER = 0.0 INCHES
TEMP = 60.3 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2839.0 GAL
PERCENT VOLUME = 56.6

LEAK TEST RESULTS
RATE = -0.01 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

HANDY SPOT
2101 E MICH BLVD
MICHIGAN CITY
219-878-9790

JUN 13, 2025 4:16 PM

LEAK TEST REPORT

T 4:RNL 25K
PROBE SERIAL NUM 228848

TEST STARTING TIME:
JUN 9, 2025 12:30 AM

HEIGHT = 42.6 INCHES
WATER = 0.8 INCHES
TEMP = 61.7 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 7992.0 GAL
PERCENT VOLUME = 31.8

LEAK TEST RESULTS
RATE = 0.12 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****


```

TEST LENGTH = 2.0 HRS
STRT VOLUME = 7992.0 GAL
PERCENT VOLUME = 31.8

START TEMP =
END TEMP = 61.7 F
           61.6 F

TEST PERIODS 2-4
0.05 0.09 0.18

LEAK TEST RESULTS
RATE = 0.12 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

```