

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
08/25/2024 17:22:06

SCALD REPORT
Last Available

units:gal, in. °F

TANKS

Unleaded
Unleaded
Capacity: 14,697.8

Begin End
08/25/2024 08/25/2024
03:56:57 08:54:19
Result Pass
Slope 0.04
Status 0
Volume Qualify % >= 14

Premium
Premium
Capacity: 6,380.0

Begin End
08/25/2024 08/25/2024
01:10:31 04:52:34
Result Pass
Slope 0.05
Status 0
Volume Qualify % >= 14

Diesel
Diesel
Capacity: 7,686.6

Begin End
08/25/2024 08/25/2024
11:49:46 14:16:28
Result Pass
Slope -0.01
Status 0
Volume Qualify % >= 14

K-1
K-1
Capacity: 2,134.5

Begin End
08/25/2024 08/25/2024
14:47:02 16:13:43
Result Pass
Slope -0.00
Status 0
Volume Qualify % >= 14

.....

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
08/25/2024 17:22:07

REGULATORY REPORT
(Passed Tests)
August 2024

units:gph

TANKS (MONTHLY)

Tank 1
Unleaded
SCALD
Slope 0.04
▶ 08/25/2024 03:56:57
▶ 08/25/2024 08:54:19
Volume Qualify % >= 14
Slope -0.01
▶ 08/21/2024 07:56:57
▶ 08/22/2024 02:41:05
Volume Qualify % >= 14

Tank 2
Premium
SCALD
Slope 0.05
▶ 08/25/2024 01:10:31
▶ 08/25/2024 04:52:34
Volume Qualify % >= 14
Slope -0.04
▶ 08/22/2024 08:02:37
▶ 08/22/2024 03:29:10
Volume Qualify % >= 14

Tank 3
Diesel
SCALD
Slope -0.01
▶ 08/25/2024 11:49:46
▶ 08/25/2024 14:16:28
Volume Qualify % >= 14
Slope 0.02
▶ 08/18/2024 04:36:10
▶ 08/18/2024 06:04:14
Volume Qualify % >= 14

Tank 4
K-1
SCALD
Slope -0.00
▶ 08/25/2024 14:47:02
▶ 08/25/2024 16:13:43
Volume Qualify % >= 14
Slope -0.01
▶ 08/12/2024 18:07:04
▶ 08/12/2024 19:35:09
Volume Qualify % >= 14