

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
12/19/2024 17:48:03

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

Unleaded
Unleaded
Capacity: 14,697

Begin En
12/18/2024 12/19/2024
23:30:54 01:17:57
Result Pas
Slope -0.1
Status
Volume Qualify % >= 1

Premium
Premium
Capacity: 6,380.

Begin En
12/19/2024 12/19/2024
01:21:22 02:50:01
Result Pas
Slope -0.0
Status
Volume Qualify % >= 1

Diesel
Diesel
Capacity: 7,686.

Begin End
12/19/2024 12/19/2024
11:43:48 17:23:00
Result Pass
Slope 0.00
Status
Volume Qualify % >= 14

K-1
K-1
Capacity: 2,134.5

Begin End
11/22/2024 11/22/2024
10:49:24 13:04:33
Result Pass
Slope -0.01
Status
Volume Qualify % >= 14

.....

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
12/19/2024 17:48:03

REGULATORY REPORT
(Passed Tests)
December 2024

units:gph

TANKS (MONTHLY)

Tank 1
Unleaded
SCALD
Slope -0.10
▶ 12/18/2024 23:30:54
▶ 12/19/2024 01:17:57
Volume Qualify % >= 14
Slope -0.00
▶ 12/06/2024 02:12:56
▶ 12/06/2024 04:13:18
Volume Qualify % >= 14

Tank 2
Premium
SCALD
Slope -0.01
▶ 12/19/2024 01:21:22
▶ 12/19/2024 02:50:01
Volume Qualify % >= 14
Slope 0.01
▶ 12/18/2024 00:18:00
▶ 12/18/2024 01:45:14
Volume Qualify % >= 14

Tank 3
Diesel
SCALD
Slope 0.00
▶ 12/19/2024 11:43:48
▶ 12/19/2024 17:23:00
Volume Qualify % >= 14
Slope -0.01
▶ 12/15/2024 23:59:37
▶ 12/16/2024 01:28:40
Volume Qualify % >= 14