

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
05/16/2024 15:09:24

TANK TEST REPORT
Last Available

units:gal, in, °F

No Records Found

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
05/16/2024 15:09:40

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

Unleaded
Unleaded
Capacity: 14,697.8

Begin End
05/16/2024 05/16/2024
02:34:03 08:52:07
Result Pass
Slope -0.06
Status 0
Volume Qualify % >= 14

Premium
Premium
Capacity: 6,380.0

Begin End
05/16/2024 05/16/2024
01:45:41 03:13:33
Result Pass
Slope -0.02
Status 0
Volume Qualify % >= 14

Diesel
Diesel
Capacity: 7,686.6

Begin End
05/16/2024 05/16/2024
12:19:26 14:32:22
Result Pass
Slope 0.09
Status 0
Volume Qualify % >= 14

K-1
K-1
Capacity: 2,134.5

Begin End
05/16/2024 05/16/2024
13:20:08 14:46:45
Result Pass
Slope 0.01
Status 0
Volume Qualify % >= 14

.....

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
05/16/2024 15:09:41

ALARMS REPORT
Last 30 Days

Unleaded
SCALD Tank Test Failed
Alarm
! 05/10/2024 02:06:05
✓ 05/10/2024 03:34:12

Check Printer
Warning
! 05/08/2024 05:02:06
✓ 05/16/2024 15:05:22

Unleaded
SCALD Tank Test Failed
Alarm
! 05/07/2024 00:48:42
✓ 05/07/2024 02:16:52

Unleaded
SCALD Tank Test Failed
Alarm
! 05/03/2024 03:12:40
✓ 05/04/2024 00:57:14

Unleaded
SCALD Tank Test Failed
Alarm
! 04/22/2024 23:55:00
✓ 04/24/2024 00:09:34

Unleaded
SCALD Tank Test Failed
Alarm
! 04/17/2024 02:49:45
✓ 04/19/2024 03:13:33
.....

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
05/16/2024 15:10:16

REGULATORY REPORT
(Passed Tests)
May 2024

units:gph

TANKS (MONTHLY)

Tank 1
Unleaded
SCALD
Slope -0.06
▶ 05/16/2024 02:34:03
▶ 05/16/2024 08:52:07
Volume Qualify % >= 14
Slope -0.10
▶ 05/01/2024 02:23:28
▶ 05/01/2024 04:12:22
Volume Qualify % >= 14

Tank 2
Premium
SCALD
Slope -0.02
▶ 05/16/2024 01:45:41
▶ 05/16/2024 03:13:33
Volume Qualify % >= 14

Tank 3
Diesel
SCALD
Slope 0.09
▶ 05/16/2024 12:19:26
▶ 05/16/2024 14:32:22
Volume Qualify % >= 14

Tank 4
K-1
SCALD
Slope 0.01
▶ 05/16/2024 13:20:08
▶ 05/16/2024 14:46:45
Volume Qualify % >= 14
Slope 0.01
▶ 05/14/2024 20:43:04
▶ 05/14/2024 22:10:22