

Petroleum Testing Services

PO BOX 146
Yorktown, IN 47396
(765) 749-5540

Email: petroleumtesting@aol.com

DATE: 12-27-2021	TIME: 4:00P
SITE ADDRESS Simars 206 N Benton Millersburg, IN 46543	

AUTOMATIC TANK GAUGE INSPECTION					
MAKE /MODEL OF ATG : INCON 550					
TANK		1	2	3	4
PRODUCT		UNL	PREM	DSL	KERO
TANK VOLUME / GALLONS		14697	6380	7686	2134
ATG LEVEL		73.16	52.70	29.24	33.20
MANUAL STICK READING		73	52	30	33
TANK DIAMETER		92	92	92	72
TANK PROBE REMOVED AND INSPECTED?		YES	YES	YES	YES
TANK PROBE HAS DAMAGED OR MISSING PARTS?		NO	NO	NO	NO
TANK PROBE DAMAGED OR MISSING PARTS REPLACED?		NA	NA	NA	NA
FLOATS MOVE FREELY ON STEM?		YES	YES	YES	YES
DOES THE FUEL FLOAT AGREE WITH CONSOLE?		YES	YES	YES	YES
DOES WATER FLOAT AGREE WITH CONSOLE?		YES	YES	YES	YES
WATER FLOAT ALARM ACTIVATION CORRESPONDS WITH CONSOLE?		YES	YES	YES	YES
OVERFILL ALARM ACTIVATION CORRESPONDS WITH CONSOLE?		YES	YES	YES	YES
.2 MONTHLY MONITORING IS ACTIVATED?		YES	YES	YES	YES
SUMP SENSORS ACTIVATE ALARM?		NA	NA	NA	NA
RESULT		PASS	PASS	PASS	PASS

INSPECTED BY: RONNIE BROWN

UC2017IN12086