

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
11/15/2024 16:22:20

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

Unleaded
Unleaded
Capacity: 14,697.8

Begin	End
11/14/2024 03:27:50	11/14/2024 06:13:06
Result	Pass
Slope	-0.07
Status	0
Volume Qualify %	>= 14

Premium
Premium
Capacity: 6,380.0

Begin	End
11/13/2024 21:11:53	11/14/2024 03:04:42
Result	Pass
Slope	0.02
Status	0
Volume Qualify %	>= 14

Diesel
Diesel
Capacity: 7,686.6

Begin	End
11/15/2024 08:18:36	11/15/2024 09:46:06
Result	Pass
Slope	-0.05
Status	0
Volume Qualify %	>= 14

K-1
K-1
Capacity: 2,134.5

Begin	End
11/15/2024 13:53:25	11/15/2024 15:19:45
Result	Pass
Slope	0.00
Status	0
Volume Qualify %	>= 14

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
11/15/2024 16:22:22

REGULATORY REPORT
(Passed Tests)
November 2024

units:gph

TANKS (MONTHLY)

Tank 1
Unleaded
SCALD
Slope -0.07
▶ 11/14/2024 03:27:50
▶ 11/14/2024 06:13:06
Volume Qualify % >= 14

Tank 2
Premium
SCALD
Slope 0.02
▶ 11/13/2024 21:11:53
▶ 11/14/2024 03:04:42
Volume Qualify % >= 14

Tank 3
Diesel
SCALD
Slope -0.05
▶ 11/15/2024 08:18:36
▶ 11/15/2024 09:46:06
Volume Qualify % >= 14

Tank 4
K-1
SCALD
Slope 0.00
▶ 11/15/2024 13:53:25
▶ 11/15/2024 15:19:45
Volume Qualify % >= 14
Slope -0.02
▶ 11/10/2024 15:52:40
▶ 11/10/2024 17:41:25
Volume Qualify % >= 14

.....

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
11/15/2024 16:22:32

TANK TEST REPORT
Last Available

units:gal, in, °F

No Records Found