

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
07/23/2024 18:26:13

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

Unleaded
Unleaded
Capacity: 14,697.8

Begin End
07/23/2024 07/23/2024
01:07:06 02:34:43
Result Fail
Slope -0.20
Status 5.013
Volume Qualify % >= 14

Premium
Premium
Capacity: 6,380.0

Begin End
07/23/2024 07/23/2024
01:07:33 02:35:19
Result Pass
Slope -0.01
Status 0
Volume Qualify % >= 14

Diesel
Diesel
Capacity: 7,686.6

Begin End
07/23/2024 07/23/2024
12:57:14 14:56:29
Result Pass
Slope 0.02
Status 0
Volume Qualify % >= 14

K-1
K-1
Capacity: 2,134.5

Begin End
07/23/2024 07/23/2024
16:54:57 18:22:53
Result Pass
Slope -0.00
Status 0
Volume Qualify % >= 14

.....

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
07/23/2024 18:26:19

REGULATORY REPORT
(Passed Tests)
July 2024

units:gph

TANKS (MONTHLY)

Tank 1
Unleaded
SCALD
Slope -0.07
▶ 07/21/2024 06:08:37
▶ 07/21/2024 07:49:51
Volume Qualify % >= 14

Tank 2
Premium
SCALD
Slope -0.01
▶ 07/23/2024 01:07:33
▶ 07/23/2024 02:35:19
Volume Qualify % >= 14

Tank 3
Diesel
SCALD
Slope 0.02
▶ 07/23/2024 12:57:14
▶ 07/23/2024 14:56:29
Volume Qualify % >= 14
Slope -0.04
▶ 07/19/2024 03:56:35
▶ 07/19/2024 06:50:56
Volume Qualify % >= 14

Tank 4
K-1
SCALD
Slope -0.00
▶ 07/23/2024 16:54:57
▶ 07/23/2024 18:22:53
Volume Qualify % >= 14
Slope -0.01
▶ 07/13/2024 18:47:22
▶ 07/13/2024 20:13:42
Volume Qualify % >= 14

.....