

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
10/23/2024 17:36:42

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

Unleaded
Unleaded
Capacity: 14,697.8

Begin	End
10/22/2024	10/22/2024
03:15:30	21:33:00
Result	Pass
Slope	-0.00
Status	0
Volume Qualify %	>= 14

Premium
Premium
Capacity: 6,380.0

Begin	End
10/22/2024	10/23/2024
22:34:33	00:03:08
Result	Pass
Slope	-0.01
Status	0
Volume Qualify %	>= 14

Diesel
Diesel
Capacity: 7,686.6

Begin	End
10/23/2024	10/23/2024
07:17:04	09:48:38
Result	Pass
Slope	0.01
Status	0
Volume Qualify %	>= 14

K-1
K-1
Capacity: 2,134.5

Begin	End
10/23/2024	10/23/2024
16:02:01	17:30:06
Result	Pass
Slope	-0.00
Status	0
Volume Qualify %	>= 14

.....

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
10/23/2024 17:36:48

REGULATORY REPORT
(Passed Tests)
October 2024

units:gph

TANKS (MONTHLY)

Tank 1

Unleaded

SCALD

Slope -0.00

▶ 10/22/2024 03:15:30

▶ 10/22/2024 21:33:00

Volume Qualify % ≥ 14

Slope -0.02

▶ 10/17/2024 02:35:56

▶ 10/17/2024 04:58:32

Volume Qualify % ≥ 14

Tank 2

Premium

SCALD

Slope -0.01

▶ 10/22/2024 22:34:33

▶ 10/23/2024 00:03:08

Volume Qualify % ≥ 14

Slope -0.05

▶ 10/19/2024 04:05:03

▶ 10/19/2024 05:32:15

Volume Qualify % ≥ 14

Tank 3

Diesel

SCALD

Slope 0.01

▶ 10/23/2024 07:17:04

▶ 10/23/2024 09:48:38

Volume Qualify % ≥ 14

Slope -0.00

▶ 10/17/2024 02:24:41

▶ 10/17/2024 03:52:58

Volume Qualify % ≥ 14

Tank 4

K-1

SCALD

Slope -0.00

▶ 10/23/2024 16:02:01

▶ 10/23/2024 17:30:06

Volume Qualify % ≥ 14

Slope 0.01

▶ 10/11/2024 17:42:10

▶ 10/11/2024 19:08:34

Volume Qualify % ≥ 14

.....