

Simar Convenience  
206 N. Benton St.  
Millersburg, IN 46543  
574-642-4400  
09/14/2024 16:00:18

SCALD REPORT  
Last Available

units:gal, in, °F

TANKS

Unleaded  
Unleaded  
Capacity: 14,697.8

|                  |            |
|------------------|------------|
| Begin            | End        |
| 09/11/2024       | 09/11/2024 |
| 08:45:05         | 23:13:38   |
| Result           | Pass       |
| Slope            | -0.10      |
| Status           | 0          |
| Volume Qualify % | >= 14      |

Premium  
Premium  
Capacity: 6,380.0

|                  |            |
|------------------|------------|
| Begin            | End        |
| 09/14/2024       | 09/14/2024 |
| 04:42:46         | 06:20:10   |
| Result           | Pass       |
| Slope            | -0.05      |
| Status           | 0          |
| Volume Qualify % | >= 14      |

Diesel  
Diesel  
Capacity: 7,686.6

|                  |            |
|------------------|------------|
| Begin            | End        |
| 09/14/2024       | 09/14/2024 |
| 12:50:35         | 14:18:30   |
| Result           | Pass       |
| Slope            | 0.01       |
| Status           | 0          |
| Volume Qualify % | >= 14      |

K-1  
K-1  
Capacity: 2,134.5

|                  |            |
|------------------|------------|
| Begin            | End        |
| 09/14/2024       | 09/14/2024 |
| 14:09:41         | 15:36:09   |
| Result           | Pass       |
| Slope            | -0.01      |
| Status           | 0          |
| Volume Qualify % | >= 14      |

.....  
Simar Convenience  
206 N. Benton St.  
Millersburg, IN 46543  
574-642-4400  
09/14/2024 16:00:19

REGULATORY REPORT  
(Passed Tests)  
September 2024

units:gph

TANKS (MONTHLY)

Tank 1  
Unleaded  
SCALD  
Slope -0.10  
▶ 09/11/2024 08:45:05  
▶ 09/11/2024 23:13:38  
Volume Qualify % >= 14

Tank 2  
Premium  
SCALD  
Slope -0.05  
▶ 09/14/2024 04:42:46  
▶ 09/14/2024 06:20:10  
Volume Qualify % >= 14

Tank 3  
Diesel  
SCALD  
Slope 0.01  
▶ 09/14/2024 12:50:35  
▶ 09/14/2024 14:18:30  
Volume Qualify % >= 14

Tank 4  
K-1  
SCALD  
Slope -0.01  
▶ 09/14/2024 14:09:41  
▶ 09/14/2024 15:36:09  
Volume Qualify % >= 14  
Slope -0.01  
▶ 09/11/2024 18:08:22  
▶ 09/11/2024 19:34:44  
Volume Qualify % >= 14

.....  
08-14-2024 16:00:19  
574-642-4400  
Millersburg, IN 46543