

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
07/31/2025 15:10:43

REGULATORY REPORT
(Passed Tests)
July 2025

units:gph

TANKS (MONTHLY)

Tank 1
Unleaded
SCALD
Slope -0.09
▶ 07/30/2025 22:14:53
▶ 07/30/2025 23:42:45
Volume Qualify % ≥ 14
Slope 0.03
▶ 06/30/2025 06:17:47
▶ 07/01/2025 04:39:44
Volume Qualify % ≥ 14
Tank 2
Premium
SCALD
Slope -0.04
▶ 07/31/2025 01:47:55
▶ 07/31/2025 03:14:52
Volume Qualify % ≥ 14
Slope -0.05
▶ 07/14/2025 23:03:05
▶ 07/15/2025 00:30:05
Volume Qualify % ≥ 14
Tank 3
Diesel
SCALD
Slope -0.03
▶ 07/31/2025 11:13:03
▶ 07/31/2025 14:06:19
Volume Qualify % ≥ 14
Slope 0.03
▶ 07/13/2025 16:02:50
▶ 07/13/2025 17:43:12
Volume Qualify % ≥ 14
Tank 4
K-1
SCALD
Slope 0.00
▶ 07/31/2025 12:36:58
▶ 07/31/2025 14:03:51
Volume Qualify % ≥ 14
Slope 0.01
▶ 07/21/2025 02:27:23
▶ 07/21/2025 03:54:00
Volume Qualify % ≥ 14
.....

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
07/31/2025 15:10:49

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

Unleaded
Unleaded
Capacity: 14,697.8
Begin End
07/30/2025 07/30/2025
22:14:53 23:42:45
Result Pass
Slope -0.09
Status 0
Volume Qualify % ≥ 14
Premium
Premium
Capacity: 6,380.0
Begin End
07/31/2025 07/31/2025
01:47:55 03:14:52
Result Pass
Slope -0.04
Status 0
Volume Qualify % ≥ 14
Diesel
Diesel
Capacity: 7,686.6
Begin End
07/31/2025 07/31/2025
11:13:03 14:06:19
Result Pass
Slope -0.03
Status 0
Volume Qualify % ≥ 14
K-1
K-1
Capacity: 2,134.5
Begin End
07/31/2025 07/31/2025
12:36:58 14:03:51
Result Pass
Slope 0.00
Status 0
Volume Qualify % ≥ 14
.....