

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
01/19/2025 18:38:03

SCALD REPORT

Last Available

units:gal, in, °F

TANKS

Unleaded
Unleaded
Capacity: 14,697.8

Begin	End
01/18/2025 02:33:36	01/18/2025 05:51:05
Result	Pass
Slope	0.04
Status	0
Volume Qualify %	>= 14

Premium
Premium
Capacity: 6,380.0

Begin	End
01/19/2025 04:55:59	01/19/2025 06:23:44
Result	Pass
Slope	-0.00
Status	0
Volume Qualify %	>= 14

Diesel
Diesel
Capacity: 7,686.6

Begin	End
01/19/2025 16:00:44	01/19/2025 17:28:34
Result	Pass
Slope	-0.01
Status	0
Volume Qualify %	>= 14

K-1
K-1
Capacity: 2,134.5

Begin	End
11/22/2024 10:49:24	11/22/2024 13:04:33
Result	Pass
Slope	-0.01
Status	0
Volume Qualify %	>= 14

.....

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
01/19/2025 18:38:04

REGULATORY REPORT

(Passed Tests)

January 2025

units:gph

TANKS (MONTHLY)

Tank 1
Unleaded
SCALD
Slope 0.04
▶ 01/18/2025 02:33:36
▶ 01/18/2025 05:51:05
Volume Qualify % >= 14

Slope -0.02
▶ 01/05/2025 01:25:34
▶ 01/05/2025 03:14:05
Volume Qualify % >= 14

Tank 2
Premium
SCALD
Slope -0.00
▶ 01/19/2025 04:55:59
▶ 01/19/2025 06:23:44
Volume Qualify % >= 14

Slope -0.03
▶ 01/16/2025 22:31:02
▶ 01/16/2025 23:59:36
Volume Qualify % >= 14

Tank 3
Diesel
SCALD
Slope -0.01
▶ 01/19/2025 16:00:44
▶ 01/19/2025 17:28:34
Volume Qualify % >= 14

Slope -0.04
▶ 01/14/2025 22:31:55
▶ 01/14/2025 23:59:26
Volume Qualify % >= 14
.....