

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
04/08/2025 18:28:13

TANK TEST REPORT
Last Available

units:gal, in, °F

No Records Found

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
04/08/2025 18:28:23

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

Unleaded
Unleaded
Capacity: 14,697.8

Begin End
04/08/2025 04/08/2025
04:10:01 10:34:59
Result Pass
Slope -0.04
Status 0
Volume Qualify % >= 14

Premium
Premium
Capacity: 6,380.0

Begin End
04/08/2025 04/08/2025
01:31:11 02:58:50
Result Pass
Slope -0.06
Status 0
Volume Qualify % >= 14

Diesel
Diesel
Capacity: 7,686.6

Begin End
04/08/2025 04/08/2025
15:53:57 17:26:53
Result Pass
Slope 0.06
Status 0
Volume Qualify % >= 14

K-1
K-1
Capacity: 2,134.5

Begin End
04/08/2025 04/08/2025
16:16:14 17:42:36
Result Pass
Slope 0.02
Status 0
Volume Qualify % >= 14

.....

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
04/08/2025 18:28:29

REGULATORY REPORT
(Passed Tests)
April 2025

units:gph

TANKS (MONTHLY)

Tank 1
Unleaded
SCALD
Slope -0.04

▶ 04/08/2025 04:10:01
▶ 04/08/2025 10:34:59
Volume Qualify % >= 14
Slope -0.10

▶ 04/04/2025 00:13:45
▶ 04/04/2025 01:41:48
Volume Qualify % >= 14

Tank 2
Premium
SCALD
Slope -0.06

▶ 04/08/2025 01:31:11
▶ 04/08/2025 02:58:50
Volume Qualify % >= 14

Tank 3
Diesel
SCALD
Slope 0.06

▶ 04/08/2025 15:53:57
▶ 04/08/2025 17:26:53
Volume Qualify % >= 14

Tank 4
K-1
SCALD
Slope 0.02

▶ 04/08/2025 16:16:14
▶ 04/08/2025 17:42:36
Volume Qualify % >= 14

.....

Simar Convenience
206 N. Benton St.
Millersburg, IN 46543
574-642-4400
04/08/2025 18:28:39

ALARMS REPORT

Last 30 Days

Unleaded
SCALD Tank Test Failed
Alarm

! 04/05/2025 02:39:34
✓ 04/06/2025 08:00:36

Unleaded
SCALD Tank Test Failed
Alarm

! 04/02/2025 02:20:51
✓ 04/04/2025 01:41:48

Unleaded
SCALD Tank Test Failed
Alarm

! 03/30/2025 23:22:38
✓ 03/31/2025 08:44:24

Unleaded
SCALD Tank Test Failed
Alarm

! 03/27/2025 00:38:38
✓ 03/27/2025 10:34:10

Check Printer
Warning

! 03/26/2025 12:00:10
✓ 04/08/2025 18:27:28

Unleaded
SCALD Tank Test Failed
Alarm

! 03/22/2025 05:24:46
✓ 03/22/2025 23:16:33

Unleaded
SCALD Tank Test Failed
Alarm

! 03/21/2025 00:28:06
✓ 03/22/2025 01:00:24

Unleaded
SCALD Tank Test Failed
Alarm

! 03/18/2025 02:04:15
✓ 03/19/2025 02:41:36

Unleaded
SCALD Tank Test Failed
Alarm

! 03/16/2025 06:47:55
✓ 03/17/2025 01:36:25

Unleaded
SCALD Tank Test Failed
Alarm

! 03/15/2025 01:01:55
✓ 03/16/2025 01:04:27

Unleaded
SCALD Tank Test Failed
Alarm

! 03/15/2025 01:01:55
✓ 03/16/2025 01:04:27